



IEC 60269-2

Edition 5.2 2024-06
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

Corrected version
2025-06



**Low-voltage fuses –
Part 2: Supplementary requirements for fuses for use by authorized persons
(fuses mainly for industrial application) – Examples of standardized systems of
fuses A to K**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.50

ISBN 978-2-8322-9247-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	15
INTRODUCTION	17
1 General scope	18
1.1 Scope	18
1.2 Normative references	18
Fuse system A – Fuses with fuse-links with blade contacts (NH fuse system)	20
1 General	20
1.1 Scope	20
2 Terms and definitions	20
3 Conditions for operation in service	21
4 Classification	21
5 Characteristics of fuses	21
5.2 Rated voltage	21
5.3.1 Rated current of the fuse-link	21
5.3.2 Rated current of the fuse-holder	21
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	21
5.6 Limits of time-current characteristics	21
5.6.1 Time-current characteristics, time-current zones and overload curves	21
5.6.2 Conventional times and currents	21
5.6.3 Gates	22
5.7.2 Rated breaking capacity	22
6 Markings	22
6.1 Markings of fuse-holders	22
6.2 Markings of fuse-links	23
7 Standard conditions for construction	23
7.1 Mechanical design	23
7.1.2 Connections, including terminals	23
7.1.3 Fuse-contacts	24
7.1.6 Construction of fuse-bases	24
7.1.7 Construction of a fuse-link	24
7.2 Insulating properties and suitability for insulation	25
7.7 I^2t characteristics	25
7.8 Overcurrent discrimination of fuse-links	26
7.9 Protection against electric shock	26
8 Tests	27
8.1.4 Arrangement of the fuse and dimensions	27
8.1.6 Testing of fuse-holders	27
8.2.4 Acceptability of test results	28
8.2.5 Resistance to tracking	28
8.3 Verification of temperature rise and power dissipation	28
8.3.1 Arrangement of the fuse and dimensions	28
8.3.2 Measurement of the temperature rise	28
8.5.5 Test method	29

8.5.8 Acceptability of test results	
8.7.4 Verification of overcurrent discrimination selectivity	30
8.9 Verification of resistance to heat	31
8.9.1 Fuse-base	32
8.9.2 Fuse-links with gripping-lugs of moulded material or of metal fixed in moulded material	32
8.10 Verification of non-deterioration of contacts.....	33
8.10.1 Arrangement of the fuse	33
8.10.2 Test method	35
8.10.3 Acceptability of test results	36
8.11 Mechanical and miscellaneous tests.....	38
FIGURES	41
Annex AA (informative) Special test for cable overload protection.....	61
AA.1 Arrangement of the fuse	61
AA.2 Test method and acceptability of test results	61
Fuse system B – Fuses with striker fuse-links with blade contacts (NH fuse system)	62
1.1 Scope.....	62
5.2 Rated voltage	62
5.3.1 Rated current of the fuse-link.....	63
5.3.2 Rated current of the fuse-holder	63
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	63
5.6 Limits of time-current characteristics	63
5.7.2 Rated breaking capacity	63
7.1 Mechanical design.....	63
7.1.2 Connections, including terminals	63
7.1.3 Fuse-contacts	63
7.1.7 Construction of a fuse-link	64
7.2 Insulating properties and suitability for insulation	64
7.7 I^2t characteristics	64
7.8 Overcurrent discrimination of "gG" fuse-links	64
7.9 Protection against electric shock	64
8.1.6 Testing of fuse-holders	64
8.3 Verification of temperature rise and power dissipation	64
8.7.4 Verification of overcurrent discrimination	65
8.9 Verification of resistance to heat	65
8.9.1 Fuse-base	65
FIGURES	67
Fuse system C – Fuse-rails (NH fuse system)	74
1.1 Scope.....	74
5.2 Rated voltage	74
5.3.2 Rated current	74
5.5.1 Rated acceptable power dissipation.....	74
7.1 Mechanical design.....	75
7.1.2 Connections, including terminals	75

7.2	Insulating properties	75
8.1.6	Testing of fuse-holders	75
8.3	Verification of temperature rise and power dissipation	76
8.3.1	Arrangement of the fuse	76
8.9	Verification of resistance to heat	77
8.9.1	Fuse-base	77
8.10	Verification of non-deterioration of contacts	77
8.10.1	Arrangement of the fuse	77
FIGURES	79

Fuse system D – Fuse-bases for busbar mounting (40 mm system) (NH fuse system)..... 84

1.1	Scope	84
5.2	Rated voltage	84
5.3.2	Rated current	85
5.5.2	Rated acceptable power dissipation of tandem fuse-bases	85
6	Markings	85
7	Standard conditions for construction	85
7.1	Mechanical design	85
7.1.2	Connections, including terminals	85
7.1.5	Construction of a fuse-base for busbar mounting	86
7.2	Insulating properties and suitability for insulation	86
8	Tests	86
8.3	Verification of temperature rise and power dissipation	86
8.3.1	Arrangement of the fuse	86
8.9.1	Fuse-base	87
8.10	Verification of non-deterioration of contacts	87
8.10.1	Arrangement of the fuse	87
8.10.2	Test method	88
8.11	Mechanical and miscellaneous tests	88
FIGURES	89

Fuse system E – Fuses with fuse-links for bolted connections (BS bolted fuse system)..... 96

1	General	96
1.1	Scope	96
2	Terms and definitions	96
3	Conditions for operation in service	96
4	Classification	96
5	Characteristics of fuses	96
5.3.1	Rated current of the fuse-link	96
5.3.2	Rated current of the fuse-holder	96
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	97
5.6	Limits of time-current characteristics	97
5.6.1	Time-current characteristics, time-current zones and overload curves	97
5.6.2	Conventional times and currents	97

5.6.3	Gates	97
5.7.2	Rated breaking capacity	97
6	Markings	97
6.1	Markings of fuse-holders	98
6.2	Markings of fuse-links.....	98
7	Standard conditions for construction.....	98
7.1	Mechanical design.....	98
7.1.2	Connections including terminals	98
7.2	Insulating properties and suitability for insulation	98
7.9	Protection against electric shock	98
8	Tests	98
8.3	Verification of temperature rise and power dissipation.....	98
8.3.1	Arrangement of the fuse	98
8.3.3	Measurement of the power dissipation of the fuse-link.....	98
8.4	Verification of operation	99
8.4.1	Arrangement of the fuse	99
8.5	Verification of breaking capacity	99
8.5.1	Arrangement of the fuse	99
8.5.8	Acceptability of test results.....	99
8.9	Verification of resistance to heat	99
8.10	Verification of non-deterioration of contacts.....	99
8.10.1	Arrangement of the fuse	99
8.10.2	Test method	99
8.10.3	Acceptability of the results.....	100
8.11	Mechanical and miscellaneous tests.....	100
	FIGURES.....	101

	Fuse system F – Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)	110
1	General	110
1.1	Scope.....	110
2	Terms and definitions	110
3	Conditions for operation in service.....	110
4	Classification.....	110
5	Characteristics of fuses	110
5.2	Rated voltage	110
5.3.1	Rated current of the fuse-link.....	111
5.3.2	Rated current of the fuse-holder	111
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	111
5.6	Limits of time-current characteristics	112
5.6.1	Time-current characteristics, time-current zones and overload curves	112
5.6.2	Conventional times and currents.....	112
5.6.3	Gates	113
5.7.2	Rated breaking capacity	113
6	Markings	113
6.1	Markings of fuse-holders	113
6.2	Markings of fuse-links.....	114

7	Standard conditions for construction	114
7.1	Mechanical design	114
7.1.2	Connections including terminals	114
7.2	Insulating properties and suitability for insulation	114
7.7	I^2t characteristics	115
7.8	Overcurrent discrimination of "gG" fuse-links	115
7.9	Protection against electric shock	115
8	Tests	115
8.1.6	Testing of fuse-holders	116
8.3.1	Arrangement of the fuse	116
8.7.4	Verification of overcurrent discrimination	118
8.9	Verification of resistance to heat	119
8.10	Verification of non-deterioration of contacts	119
8.10.1	Arrangement of the fuse	119
8.10.2	Test method	119
8.10.3	Acceptability of test results	120
	FIGURES	121

Fuse system G – Fuses with fuse-links with offset blade contacts (BS clip-in fuse system) 125

1	General	125
1.1	Scope	125
2	Terms and definitions	125
3	Conditions for operation in service	125
4	Classification	125
5	Characteristics of fuses	125
5.2	Rated voltage	126
5.3.1	Rated current of the fuse-link	126
5.3.2	Rated current of the fuse-holder	126
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	126
5.6.1	Time-current characteristics, time-current zones	126
5.6.2	Conventional times and currents	126
5.6.3	Gates	126
5.7.2	Rated breaking capacity	127
6	Markings	127
6.1	Markings of fuse-holders	127
6.2	Markings of fuse-links	127
7	Standard conditions for construction	127
7.1	Mechanical design	127
7.1.2	Connections including terminals	127
7.2	Insulating properties and suitability for insulation	128
7.7	I^2t characteristics	128
7.9	Protection against electric shock	128
8	Tests	128
8.3.3	Measurement of the power dissipation of the fuse-link	128
8.4.1	Arrangement of the fuse	129

8.5.1	Arrangement of the fuse	129
8.7.4	Verification of overcurrent discrimination	129
8.9	Verification of resistance to heat	129
8.10	Verification of non-deterioration of contacts.....	129
8.10.1	Arrangement of the fuse	129
8.10.2	Test method	130
8.10.3	Acceptability of test results.....	130
8.11	Mechanical and miscellaneous tests.....	130
FIGURES		131

Fuse system H – Fuses with fuse-links having "gD" and "gN" characteristics (class J, class T, and class L time delay and non time delay fuse types).....	136	
1	General	136
1.1	Scope.....	136
2	Terms and definitions	136
3	Conditions for operation in service.....	136
4	Classification.....	136
5	Characteristics of fuses	136
5.2	Rated voltage	136
5.3.1	Rated current of the fuse-link.....	137
5.3.2	Rated current of the fuse-holder	137
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	137
5.6	Limits of the time-current characteristics	137
5.6.1	Time-current characteristics, time-current zones	137
5.6.2	Conventional times and currents.....	137
5.6.3	Gates	137
5.7.2	Rated breaking capacity	138
6	Markings	138
6.1	Markings of fuse-holders	138
6.2	Markings of fuse-links.....	138
7	Standard conditions for construction.....	138
7.1	Mechanical design.....	138
7.2	Insulating properties and suitability for insulation	138
7.5	Breaking capacity.....	138
7.6	Cut-off current characteristics.....	139
7.7	I^2t characteristics	139
7.8	Overcurrent discrimination.....	140
7.9	Protection against electric shock	140
8	Tests	140
8.3	Verification of temperature rise and power dissipation	140
8.3.1	Arrangement of the fuse	140
8.4	Verification of operation	141
8.4.1	Arrangement of the fuse	141
8.5.4	Recovery voltage.....	142
8.6	Verification of cut-off current characteristics	142
8.7	Verification of I^2t characteristics and overcurrent discrimination.....	143
8.9	Verification of resistance to heat	143

8.10	Verification of non-deterioration of contacts.....	143
8.10.1	Arrangement of the fuse	143
8.10.2	Test method	144
8.10.3	Acceptability of test results	144
8.11	Mechanical and miscellaneous tests.....	144
8.11.2	Miscellaneous tests	144
FIGURES		145

Fuse system I – gU fuse-links with wedge tightening contacts..... 158

1	General	158
1.1	Scope.....	158
2	Terms and definitions	158
3	Conditions for operation in service.....	159
3.9	Discrimination of fuse-links.....	159
4	Classification.....	159
5	Characteristics of fuses	159
5.2	Rated voltage	159
5.3.1	Rated current of the fuse-link.....	159
5.5	Rated power dissipation of a fuse-link	159
5.6.1	Time-current characteristics, time-current zones	159
5.6.2	Conventional times and currents.....	160
5.6.3	Gates	160
5.7.2	Rated breaking capacity	160
5.8	Cut-off current and I^2t characteristics.....	160
6	Markings	160
6.1	Markings of fuse-holders	160
6.2	Markings of fuse-links.....	160
7	Standard conditions for construction.....	160
7.1	Mechanical design.....	160
7.2	Insulating properties and suitability for insulation	160
7.5	Breaking capacity	160
7.7	I^2t characteristics	161
7.8	Overcurrent discrimination of the fuse-links	161
8	Tests	161
8.1.1	Kind of tests	161
8.3.1	Arrangement of the fuse	161
8.3.3	Measurement of the power dissipation of the fuse-link.....	162
8.4.1	Arrangement of the fuse	162
8.5.1	Arrangement of the fuse	162
8.5.2	Characteristics of the test circuit.....	162
8.5.5	Test method	162
8.5.8	Acceptability of test results	162
8.7.3	Verification of compliance for fuse-links at 0,01 s	163
8.9	Verification of resistance to heat	163
8.11	Mechanical and miscellaneous tests.....	163
FIGURES		164

Fuse system J – Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types).....	172
1 General	172
1.1 Scope.....	172
2 Terms and definitions	172
3 Conditions for operation in service.....	172
4 Classification.....	172
5 Characteristics of fuses	172
5.2 Rated voltage	172
5.3.1 Rated current of the fuse-link.....	173
5.3.2 Rated current of the fuse-holder	173
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	173
5.6 Limits of the time-current characteristics	173
5.6.1 Time-current characteristics, time-current zones	173
5.6.2 Conventional times and currents.....	173
5.6.3 Gates	173
5.7.2 Rated breaking capacity	173
6 Markings	174
6.1 Markings of fuse-holders	174
6.2 Markings of fuse-links.....	174
7 Standard conditions for construction.....	174
7.1 Mechanical design.....	174
7.2 Insulating properties and suitability for insulation	174
7.5 Breaking capacity	174
7.6 Cut-off current characteristics.....	174
7.7 I^2t characteristics	174
7.8 Overcurrent discrimination.....	175
7.9 Protection against electric shock	175
8 Tests	175
8.3 Verification of temperature rise and power dissipation	175
8.3.1 Arrangement of the fuse	175
8.4 Verification of operation	176
8.4.1 Arrangement of the fuse	176
8.5.4 Recovery voltage.....	176
8.6 Verification of cut-off current characteristics	176
8.7 Verification of I^2t characteristics and overcurrent discrimination.....	177
8.9 Verification of resistance to heat	178
8.10 Verification of non-deterioration of contacts.....	178
8.10.1 Arrangement of the fuse	178
8.10.2 Test method	178
8.10.3 Acceptability of test results	178
8.11 Mechanical and miscellaneous tests	178
8.11.2 Miscellaneous tests	179
FIGURES.....	180

Fuse system K – gK fuse-links with blade contacts for bolted connections – High current fuse-link ratings from 1 250 A up to 4 800A (Master fuse-links).....	190
1 General	190
1.1 Scope.....	190
2 Terms and definitions	190
3 Conditions for operation in service.....	190
3.9 Discrimination of fuse-links.....	190
4 Classification.....	190
5 Characteristics of fuses	190
5.2 Rated voltage	191
5.3.1 Rated current of the fuse-link.....	191
5.3.2 Rated current of the fuse-holder	191
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	191
5.6 Limits of the time-current characteristics	191
5.6.1 Time-current characteristics, time-current zones	191
5.6.2 Conventional times and currents.....	192
5.6.3 Gates	192
5.7.2 Rated breaking capacity	192
6 Markings	192
6.2 Markings of fuse-links.....	193
7 Standard conditions for construction.....	193
7.1 Mechanical design.....	193
7.1.3 Fuse-contacts.....	193
7.6 Cut-off current characteristics.....	193
7.7 I^2t characteristics	193
7.8 Over-current selectivity of "gK" fuse-links	193
7.9 Protection against electric shock	193
8 Tests	194
8.3 Verification of temperature rise and power dissipation.....	194
8.3.1 Arrangement of the fuse	194
8.4.1 Arrangement of the fuse	194
8.6 Verification of cut-off current characteristics	194
8.7 Verification of I^2t characteristics and over-current selectivity	195
8.9 Verification of resistance to heat	196
8.10 Verification of non-deterioration of contacts.....	196
8.10.1 Arrangement of the fuse	196
8.10.2 Test method	196
8.10.3 Acceptability of test results	196
FIGURES.....	197
Bibliography.....	204
Figure 101 – Fuse-links with blade contacts (1 of 3)	41
Figure 102 – Fuse-bases for fuse-links with blade contacts	47
Figure 103 – Replacement handle.....	48
Figure 104 – Time-current zones for "gG" fuse-links (1 of 5)	49
Figure 105 – Dummy fuse-link according to 8.3.4.1, 8.9.1 and 8.10	54

Figure 106 – Measuring points according to 8.3.4 of IEC 60269-1, 8.3.4.1, 8.3.4.2 and 8.10.2 of fuse system A	55
Figure 107 – Test knife according to 8.5.5.1.2	55
Figure 108 – Example of a measuring device for determining the withdrawal forces according to 8.9.1 and 8.11.1.2	56
Figure 109 – Facility for verifying the mechanical strength of gripping-lugs (see 8.11.1.8)	57
Figure 110 – Measuring points according to 8.10.2	58
Figure 111 – Reference fuse-base	59
Figure 112 – Design mark for isolated gripping-lugs	60
Figure 201 – Fuse-links with blade contacts with striker (1 of 4)	67
Figure 202 – Fuse-bases for fuse-links with blade contacts with striker (1 of 3)	71
Figure 301 – Fuse-rails for fuse-links with blade contacts (1 of 3)	79
Figure 302 – Test arrangement for fuse-rails (1 of 2)	82
Figure 401 – Busbar mounting bases, 1 pole	89
Figure 402 – Busbar mounting bases, 3 pole	90
Figure 403 – Busbar mounting base, size 00, 2 × 3 pole (tandem fuse-base)	91
Figure 404 – Test arrangement for single-pole and triple-pole fuse-bases for busbar-mounting according to 8.3.1	92
Figure 405 – Test arrangement for two single-pole and six single-pole fuse-bases in tandem arrangement for busbar-mounting according to 8.3.1	93
Figure 406 – Test arrangement for the verification of the peak withstand current	94
Figure 407 – Dummy fuse-link	95
Figure 501 – Fuse-links for bolted connection – Sizes A, B, C and D (1 of 2)	101
Figure 502 – Typical fuse-holder (1 of 2)	103
Figure 503 – Time-current zones for "gG" fuse-link	105
Figure 504 – Time-current zones for "gG" fuse-link	106
Figure 505 – Power dissipation test rig	107
Figure 506 – Breaking capacity test rig for fuse-links for bolted connection (1 of 2)	108
Figure 601 – Fuse-links with cylindrical caps	121
Figure 602 – Fuse-links with cylindrical contact caps with striker – Additional dimensions for sizes 14 × 51 and 22 × 58 only	122
Figure 603 – Base for fuse-links with cylindrical caps (1 of 2)	123
Figure 701 – Fuse-links having offset blade contacts, sizes E1, F1, F2 and F3	131
Figure 702 – Typical fuse-holder	132
Figure 703 – Time-current zones for "gG" fuse-links	133
Figure 704 – Time-current zones for "gG" fuse-links	134
Figure 705 – Power dissipation test rig	135
Figure 801 – Class J fuse-links (1 A to 600 A)	145
Figure 802 – Class L fuse-links (700 A to 6 000 A)	146
Figure 803 – Fuse-base and contacts for class J fuse-links 1 A to 600 A	147
Figure 804 – Fuse-base and contacts for class L fuse-links 700 A to 6 000 A	148
Figure 805 – Class T fuse-links (1 A to 1 200 A)	149
Figure 806 – Fuse-base and contacts for class T fuse-links 1 A to 1 200 A	150
Figure 807 – Temperature test arrangement	151

Figure 808 – Time-current zones for "gN" fuse-links	152
Figure 809 – Time-current zones for "gN" fuse-links	153
Figure 810 – Time-current zones for "gN" fuse-links	154
Figure 811 – Time-current zones for "gD" fuse-links	155
Figure 812 – Time-current zones for "gD" fuse-links	156
Figure 813 – Time-current zones for "gD" fuse-links	157
Figure 901 – Time-current zones for current ratings 100 A, 200 A, 355 A and 630 A	164
Figure 902 – Time-current zones for current ratings 160 A and 315 A	165
Figure 903 – Time-current zones for current ratings 250 A and 500 A	166
Figure 904 – Time-current zones for current ratings 200 A and 400 A	167
Figure 905 – Dimensions for fuse-links with L type and U type tags	168
Figure 906 – Power dissipation test rig	169
Figure 907 – Breaking capacity test rig (1 of 2)	170
Figure 1001 – Class CC fuse-links (1 A to 30 A)	180
Figure 1002 – Fuse-base and contacts for class CC fuse-links 1 A to 30 A	180
Figure 1003 – Class CC dummy fuse-link dimensions	181
Figure 1004 – Temperature test arrangement	182
Figure 1005 – Time-current zones for class CC "gN" fuses	183
Figure 1006 – Time-current zones for class CC "gN" fuses	184
Figure 1007 – Time-current zones for class CC "gN" fuses	186
Figure 1008 – Time-current zones for class CC "gD" fuses	187
Figure 1009 – Time-current zones for class CC "gD" fuses	188
Figure 1010 – Time-current zones for class CC "gD" fuses	189
Figure 1101 – "gK" fuse-links (1 of 2)	197
Figure 1102 – Connecting dimensions for "gK" fuse-links (1 of 3)	199
Figure 1103 – Dummy fuse-link	201
Figure 1104 – Time-current zones for "gK" fuse system K (1 of 2)	202
 Table 101 – Conventional time and current for "gG" fuse-links with rated current lower than 16 A	22
Table 102 – Gates for specified pre-arching and operating times of "gG" fuse-links	22
Table 103 – Minimum rated breaking capacities	22
Table 104 – Marking of fuse-links	23
Table 105 – Minimum cross-sectional ranges of unprepared conductors	24
Table 106 – Pre-arching and operating I^2t values at 0,01 s for "gG" fuse-links	25
Table 107 – Maximum operating I^2t values for "aM" fuse-links	26
Table 108 – Pre-arching I^2t values for discrimination of gG fuse-links	26
Table 109 – Survey of tests on fuse-holders and number of fuse-holders to be tested	27
Table 110 – Rated impulse withstand voltage	27
Table 111 – Torque to be applied to the terminal screws	28
Table 112 – Test currents	29
Table 113 – Test currents and I^2t limits for discrimination selectivity test	31
Table 114 – Torques to be applied when no values are given by the manufacturer	34

Table 115 – Cross-sectional area of aluminium conductors for tests corresponding to 8.10	34
Table 116 – Test sequence for direct terminal clamps.....	36
Table 117 – Permissible changes of the resistance.....	37
Table 118 – Force to withdraw the fuse-link from the fuse-base contacts	38
Table 201 – Position and force of the striker	64
Table 301 – Minimum cross-sectional ranges of unprepared conductors for fuse-rails.....	75
Table 302 – Survey of complete tests on fuse-rails and number of fuse-rails to be tested	76
Table 401 – Minimum cross-sectional ranges of unprepared conductors for fuse-bases for busbar mounting.....	85
Table 402 – Torques to be applied to contact making screws.....	86
Table 403 – Test currents	87
Table 404 – Force to withdraw the fuse-link from the fuse-base contacts	88
Table 501 – Conventional time and current for "gG" fuse-links	97
Table 502 – Gates for specified pre-arcing times of "gG" fuse-links	97
Table 601 – Maximum rated current of fuse-links with cylindrical caps	111
Table 602 – Maximum rated current of fuse-holders.....	111
Table 603 – Maximum values of the rated power dissipation of a fuse-link	112
Table 604 – Rated acceptable power dissipation of a fuse-holder	112
Table 605 – Conventional time and current for "gG" fuse-links with rated current lower than 16 A	113
Table 606 – Gates for specified pre-arcing and operating times of "gG" fuse-links with rated current lower than 16 A.....	113
Table 607 – Minimum rated breaking capacities.....	113
Table 608 – Marking of fuse-links	114
Table 609 – Minimum range of cross-sections for rigid copper conductors	114
Table 610 – Pre-arcing and operating i^2t values at 0,01 s for "gG" fuse-links	115
Table 611 – Maximum operating i^2t values for "aM" fuse-links	115
Table 612 – Survey of tests on fuse-holders and number of fuse-holders to be tested	116
Table 613 – Torque to be applied to the terminal screws	116
Table 614 – Test currents	117
Table 615 – Test currents and i^2t limits for discrimination test.....	119
Table 701 – Conventional time and current for "gG" fuse-links	126
Table 702 – Gates for specified pre-arcing times of "gG" fuse-links	127
Table 703 – Sizes of copper conductors	128
Table 704 – Pre-arcing i^2t values at 0,01 s for "gG" fuse-links	128
Table 801 – Conventional time and current for "gD" and "gN" fuse-links	137
Table 802 – Gates for specified pre-arcing times of "gD" and "gN" fuse-links	138
Table 803 – Pre-arcing i^2t values at 0,01 s for "gD" and "gN" fuse-links	139
Table 804 – Cross-sectional area of copper conductors for tests corresponding to 8.3 and 8.4	140
Table 805 – Class J dummy fuse-link dimensions	141
Table 806 – Class T dummy fuse-link dimensions	141

Table 807 – Maximum cut-off current (I_C) for "gD" and "gN" fuse-links at 200 kA prospective current	142
Table 808 – Maximum operating I^2t values for "gD" and "gN" fuse-links at 200 kA prospective current	143
Table 901 – Maximum power dissipation values	159
Table 902 – Pre-arcing I^2t values for gU fuse-links at 0,01 s	161
Table 903 – Cross-sectional area of conductors for power dissipation and temperature-rise tests	162
Table 1001 – Conventional time and current for "gD class CC" and "gN class CC" fuse-links	173
Table 1002 – Gates for specified pre-arcing times of "gD class CC" and "gN class CC" fuse-links	173
Table 1003 – Pre-arcing I^2t values at 0,01 s for "gD class CC" and "gN class CC" fuse-links	175
Table 1005 – Maximum cut-off current (I_C) for "gD class CC" and "gN class CC" fuse-links at 200 kA prospective current	177
Table 1006 – Maximum operating I^2t values for "gD class CC" and "gN class CC" fuse-links at 200 kA prospective current	177
Table 1101 – Maximum power dissipation values for «gK» fuse-links	191
Table 1102 – Conventional time and current for «gK» fuse-links	192
Table 1103 – Gates for specified pre-arcing and operating times of "gK" fuse-links	192
Table 1104 – Minimum rated breaking capacities for "gK" fuse-links	192
Table 1105 – Pre-arcing and operating I^2t values at 0,01 s for "gK" fuse-links	193
Table 1106 – Cross-sectional area of copper conductors for tests corresponding to 8.3 and 8.4	194
Table 1107 – Maximum cut-off current (I_C) for "gK" fuse-links (1 250 A to 4 800 A) at 100 kA prospective current	195
Table 1108 – Test currents and I^2t limits for "gK" fuse-links selectivity test	195

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60269-2 edition 5.2 contains the fifth edition (2013-07) [documents 32B/611/FDIS and 32B/615/RVD], its amendment 1 (2016-08) [documents 32B/641/CDV and 32B/648/RVC] and its amendment 2 (2024-06) [documents 32B/743/FDIS and 32B/755/RVD] and its corrigendum 1 (2025-06).

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in

strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60269-2 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

This edition includes the following significant technical changes with respect to the previous edition:

- a) fuse systems A and B: modified values for the power dissipation of NH aM fuse-links;
- b) fuse systems A and B: introduction of dimension r for NH fuse-links;
- c) addition of new fuse system K: gK fuse-links with contacts for bolted connections.

This part is to be used in conjunction with IEC 60269-1:2006, *Low-voltage fuses – Part 1: General requirements* and its Amendment 1 (2009).

This Part 2 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 2 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 101 in fuse system A, from 201 in fuse system B, etc. Additional annexes are numbered AA, BB, etc.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60269 series, published under the general title *Low-voltage fuses*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendments will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

- Part 1: General requirements
- Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K
- Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F
- Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices
- Part 5: Guidance for the application of low-voltage fuses
- Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

1 General scope

1.1 Scope

Fuses for use by authorized persons are generally designed to be used in installations where the fuse-links are accessible to, and may be replaced by, authorized persons only.

Fuses for use by authorized persons according to the following fuse systems also comply with the requirements of the corresponding subclauses of IEC 60269-1, unless otherwise defined in this standard.

This standard is divided into fuse systems, each dealing with a specific example of standardized fuses for use by authorized persons:

- Fuse system A: Fuses with fuse-links with blade contacts (NH fuse system)
- Fuse system B: Fuses with striker fuse-links with blade contacts (NH fuse system)
- Fuse system C: Fuse-rails (NH fuse system)
- Fuse system D: Fuse-bases for busbar mounting (NH fuse system)
- Fuse system E: Fuses with fuse-links for bolted connections (BS bolted fuse system)
- Fuse system F: Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)
- Fuse system G: Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)
- Fuse system H: Fuses with fuse-links having "gD" and "gN" characteristic (class J class L and class T time delay and non time delay fuse types)
- Fuse system I: gU fuse-links with wedge tightening contacts
- Fuse system J: Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)
- Fuse system K: gK fuse-links with blade for bolted connections – High fuse-link ratings from 1 250 A up to 4 800 A (master fuse-links)

NOTE The above-mentioned fuse systems are standardized systems in respect to their safety aspects. The National Committees can select from the examples of standardized fuses one or more systems for their own standards.

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60269-1, *Low-voltage fuses – Part 1: General requirements*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60999 (all parts), *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 60999-2, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 2: Particular requirements for clamping units for conductors above 35 mm² up to 300 mm² (included)*

~~ISO 6988, Metallic and other non-organic coatings – Sulfur dioxide test with general condensation of moisture~~

ISO 22479, *Corrosion of metals and alloys – Sulfur dioxide test in a humid atmosphere (fixed gas method)*

CONTENTS

FOREWORD	15
INTRODUCTION	17
1 General scope	18
1.1 Scope	18
1.2 Normative references	18
Fuse system A – Fuses with fuse-links with blade contacts (NH fuse system)	20
1 General	20
1.1 Scope	20
2 Terms and definitions	20
3 Conditions for operation in service	21
4 Classification	21
5 Characteristics of fuses	21
5.2 Rated voltage	21
5.3.1 Rated current of the fuse-link	21
5.3.2 Rated current of the fuse-holder	21
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	21
5.6 Limits of time-current characteristics	21
5.6.1 Time-current characteristics, time-current zones and overload curves	21
5.6.2 Conventional times and currents	21
5.6.3 Gates	22
5.7.2 Rated breaking capacity	22
6 Markings	22
6.1 Markings of fuse-holders	22
6.2 Markings of fuse-links	23
7 Standard conditions for construction	23
7.1 Mechanical design	23
7.1.2 Connections, including terminals	23
7.1.3 Fuse-contacts	24
7.1.6 Construction of fuse-bases	24
7.1.7 Construction of a fuse-link	24
7.2 Insulating properties and suitability for insulation	25
7.7 I^2t characteristics	25
7.8 Overcurrent discrimination of fuse-links	26
7.9 Protection against electric shock	26
8 Tests	27
8.1.4 Arrangement of the fuse and dimensions	27
8.1.6 Testing of fuse-holders	27
8.2.4 Acceptability of test results	28
8.2.5 Resistance to tracking	28
8.3 Verification of temperature rise and power dissipation	28
8.3.1 Arrangement of the fuse and dimensions	28
8.3.2 Measurement of the temperature rise	28
8.5.5 Test method	29

8.7.4	Verification of overcurrent selectivity	30
8.9	Verification of resistance to heat	31
8.9.1	Fuse-base	32
8.9.2	Fuse-links with gripping-lugs of moulded material or of metal fixed in moulded material	32
8.10	Verification of non-deterioration of contacts	33
8.10.1	Arrangement of the fuse	33
8.10.2	Test method	35
8.10.3	Acceptability of test results	36
8.11	Mechanical and miscellaneous tests	38
FIGURES		41
Annex AA (informative) Special test for cable overload protection	58	
AA.1	Arrangement of the fuse	58
AA.2	Test method and acceptability of test results	58
Fuse system B – Fuses with striker fuse-links with blade contacts (NH fuse system)		59
1.1	Scope	59
5.2	Rated voltage	59
5.3.1	Rated current of the fuse-link	60
5.3.2	Rated current of the fuse-holder	60
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	60
5.6	Limits of time-current characteristics	60
5.7.2	Rated breaking capacity	60
7.1	Mechanical design	60
7.1.2	Connections, including terminals	60
7.1.3	Fuse-contacts	60
7.1.7	Construction of a fuse-link	61
7.2	Insulating properties and suitability for insulation	61
7.7	I^2t characteristics	61
7.8	Overcurrent discrimination of "gG" fuse-links	61
7.9	Protection against electric shock	61
8.1.6	Testing of fuse-holders	61
8.3	Verification of temperature rise and power dissipation	61
8.7.4	Verification of overcurrent discrimination	62
8.9	Verification of resistance to heat	62
8.9.1	Fuse-base	62
FIGURES		64
Fuse system C – Fuse-rails (NH fuse system)		71
1.1	Scope	71
5.2	Rated voltage	71
5.3.2	Rated current	71
5.5.1	Rated acceptable power dissipation	71
7.1	Mechanical design	72
7.1.2	Connections, including terminals	72
7.2	Insulating properties	72

8.1.6	Testing of fuse-holders	72
8.3	Verification of temperature rise and power dissipation	73
8.3.1	Arrangement of the fuse	73
8.9	Verification of resistance to heat	74
8.9.1	Fuse-base	74
8.10	Verification of non-deterioration of contacts	74
8.10.1	Arrangement of the fuse	74
FIGURES		76

Fuse system D – Fuse-bases for busbar mounting (40 mm system) (NH fuse system).....	81
--	-----------

1.1	Scope	81
5.2	Rated voltage	81
5.3.2	Rated current	82
5.5.2	Rated acceptable power dissipation of tandem fuse-bases	82
6	Markings	82
7	Standard conditions for construction	82
7.1	Mechanical design	82
7.1.2	Connections, including terminals	82
7.1.5	Construction of a fuse-base for busbar mounting	83
7.2	Insulating properties and suitability for insulation	83
8	Tests	83
8.3	Verification of temperature rise and power dissipation	83
8.3.1	Arrangement of the fuse	83
8.9.1	Fuse-base	84
8.10	Verification of non-deterioration of contacts	84
8.10.1	Arrangement of the fuse	84
8.10.2	Test method	85
8.11	Mechanical and miscellaneous tests	85
FIGURES		86

Fuse system E – Fuses with fuse-links for bolted connections (BS bolted fuse system).....	93
--	-----------

1	General	93
1.1	Scope	93
2	Terms and definitions	93
3	Conditions for operation in service	93
4	Classification	93
5	Characteristics of fuses	93
5.3.1	Rated current of the fuse-link	93
5.3.2	Rated current of the fuse-holder	93
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	94
5.6	Limits of time-current characteristics	94
5.6.1	Time-current characteristics, time-current zones and overload curves	94
5.6.2	Conventional times and currents	94
5.6.3	Gates	94

5.7.2	Rated breaking capacity	94
6	Markings	94
6.1	Markings of fuse-holders	95
6.2	Markings of fuse-links.....	95
7	Standard conditions for construction.....	95
7.1	Mechanical design.....	95
7.1.2	Connections including terminals	95
7.2	Insulating properties and suitability for insulation	95
7.9	Protection against electric shock	95
8	Tests	95
8.3	Verification of temperature rise and power dissipation.....	95
8.3.1	Arrangement of the fuse	95
8.3.3	Measurement of the power dissipation of the fuse-link.....	95
8.4	Verification of operation	96
8.4.1	Arrangement of the fuse	96
8.5	Verification of breaking capacity	96
8.5.1	Arrangement of the fuse	96
8.5.8	Acceptability of test results	96
8.9	Verification of resistance to heat	96
8.10	Verification of non-deterioration of contacts.....	96
8.10.1	Arrangement of the fuse	96
8.10.2	Test method	96
8.10.3	Acceptability of the results.....	97
8.11	Mechanical and miscellaneous tests.....	97
FIGURES		98

Fuse system F – Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)	107	
1	General	107
1.1	Scope.....	107
2	Terms and definitions	107
3	Conditions for operation in service.....	107
4	Classification.....	107
5	Characteristics of fuses	107
5.2	Rated voltage	107
5.3.1	Rated current of the fuse-link.....	108
5.3.2	Rated current of the fuse-holder	108
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	108
5.6	Limits of time-current characteristics	109
5.6.1	Time-current characteristics, time-current zones and overload curves	109
5.6.2	Conventional times and currents.....	109
5.6.3	Gates	110
5.7.2	Rated breaking capacity	110
6	Markings	110
6.1	Markings of fuse-holders	110
6.2	Markings of fuse-links.....	111
7	Standard conditions for construction.....	111

7.1	Mechanical design.....	111
7.1.2	Connections including terminals	111
7.2	Insulating properties and suitability for insulation	111
7.7	I^2t characteristics.....	112
7.8	Overcurrent discrimination of "gG" fuse-links.....	112
7.9	Protection against electric shock	112
8	Tests	112
8.1.6	Testing of fuse-holders	113
8.3.1	Arrangement of the fuse	113
8.7.4	Verification of overcurrent discrimination	115
8.9	Verification of resistance to heat	116
8.10	Verification of non-deterioration of contacts.....	116
8.10.1	Arrangement of the fuse	116
8.10.2	Test method	116
8.10.3	Acceptability of test results	117
FIGURES	118

Fuse system G – Fuses with fuse-links with offset blade contacts (BS clip-in fuse system).....	122	
1	General	122
1.1	Scope.....	122
2	Terms and definitions	122
3	Conditions for operation in service.....	122
4	Classification	122
5	Characteristics of fuses	122
5.2	Rated voltage	123
5.3.1	Rated current of the fuse-link.....	123
5.3.2	Rated current of the fuse-holder	123
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	123
5.6.1	Time-current characteristics, time-current zones	123
5.6.2	Conventional times and currents.....	123
5.6.3	Gates	123
5.7.2	Rated breaking capacity	124
6	Markings	124
6.1	Markings of fuse-holders	124
6.2	Markings of fuse-links.....	124
7	Standard conditions for construction.....	124
7.1	Mechanical design.....	124
7.1.2	Connections including terminals	124
7.2	Insulating properties and suitability for insulation	125
7.7	I^2t characteristics.....	125
7.9	Protection against electric shock	125
8	Tests	125
8.3.3	Measurement of the power dissipation of the fuse-link.....	125
8.4.1	Arrangement of the fuse	126
8.5.1	Arrangement of the fuse	126

8.7.4	Verification of overcurrent discrimination	126
8.9	Verification of resistance to heat	126
8.10	Verification of non-deterioration of contacts.....	126
8.10.1	Arrangement of the fuse	126
8.10.2	Test method	127
8.10.3	Acceptability of test results	127
8.11	Mechanical and miscellaneous tests.....	127
FIGURES		128

Fuse system H – Fuses with fuse-links having "gD" and "gN" characteristics (class J, class T, and class L time delay and non time delay fuse types).....	133	
1	General	133
1.1	Scope.....	133
2	Terms and definitions	133
3	Conditions for operation in service.....	133
4	Classification.....	133
5	Characteristics of fuses	133
5.2	Rated voltage	133
5.3.1	Rated current of the fuse-link.....	134
5.3.2	Rated current of the fuse-holder	134
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	134
5.6	Limits of the time-current characteristics	134
5.6.1	Time-current characteristics, time-current zones	134
5.6.2	Conventional times and currents.....	134
5.6.3	Gates	134
5.7.2	Rated breaking capacity	135
6	Markings	135
6.1	Markings of fuse-holders	135
6.2	Markings of fuse-links.....	135
7	Standard conditions for construction.....	135
7.1	Mechanical design.....	135
7.2	Insulating properties and suitability for insulation	135
7.5	Breaking capacity	135
7.6	Cut-off current characteristics.....	136
7.7	I^2t characteristics	136
7.8	Overcurrent discrimination.....	137
7.9	Protection against electric shock	137
8	Tests	137
8.3	Verification of temperature rise and power dissipation.....	137
8.3.1	Arrangement of the fuse	137
8.4	Verification of operation	138
8.4.1	Arrangement of the fuse	138
8.5.4	Recovery voltage.....	139
8.6	Verification of cut-off current characteristics	139
8.7	Verification of I^2t characteristics and overcurrent discrimination.....	140
8.9	Verification of resistance to heat	140
8.10	Verification of non-deterioration of contacts.....	140

8.10.1	Arrangement of the fuse	140
8.10.2	Test method	141
8.10.3	Acceptability of test results	141
8.11	Mechanical and miscellaneous tests	141
8.11.2	Miscellaneous tests	141
FIGURES		142
Fuse system I – gU fuse-links with wedge tightening contacts.....		155
1	General	155
1.1	Scope.....	155
2	Terms and definitions	155
3	Conditions for operation in service.....	156
3.9	Discrimination of fuse-links.....	156
4	Classification	156
5	Characteristics of fuses	156
5.2	Rated voltage	156
5.3.1	Rated current of the fuse-link.....	156
5.5	Rated power dissipation of a fuse-link	156
5.6.1	Time-current characteristics, time-current zones	156
5.6.2	Conventional times and currents.....	157
5.6.3	Gates	157
5.7.2	Rated breaking capacity	157
5.8	Cut-off current and I^2t characteristics.....	157
6	Markings	157
6.1	Markings of fuse-holders	157
6.2	Markings of fuse-links.....	157
7	Standard conditions for construction	157
7.1	Mechanical design.....	157
7.2	Insulating properties and suitability for insulation	157
7.5	Breaking capacity	157
7.7	I^2t characteristics	158
7.8	Overcurrent discrimination of the fuse-links	158
8	Tests	158
8.1.1	Kind of tests	158
8.3.1	Arrangement of the fuse	158
8.3.3	Measurement of the power dissipation of the fuse-link	159
8.4.1	Arrangement of the fuse	159
8.5.1	Arrangement of the fuse	159
8.5.2	Characteristics of the test circuit.....	159
8.5.5	Test method	159
8.5.8	Acceptability of test results	159
8.7.3	Verification of compliance for fuse-links at 0,01 s	160
8.9	Verification of resistance to heat	160
8.11	Mechanical and miscellaneous tests	160
FIGURES		161

Fuse system J – Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types).....	169
1 General	169
1.1 Scope.....	169
2 Terms and definitions	169
3 Conditions for operation in service.....	169
4 Classification.....	169
5 Characteristics of fuses	169
5.2 Rated voltage	169
5.3.1 Rated current of the fuse-link.....	170
5.3.2 Rated current of the fuse-holder	170
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	170
5.6 Limits of the time-current characteristics	170
5.6.1 Time-current characteristics, time-current zones	170
5.6.2 Conventional times and currents.....	170
5.6.3 Gates	170
5.7.2 Rated breaking capacity	170
6 Markings	171
6.1 Markings of fuse-holders	171
6.2 Markings of fuse-links.....	171
7 Standard conditions for construction.....	171
7.1 Mechanical design.....	171
7.2 Insulating properties and suitability for insulation	171
7.5 Breaking capacity	171
7.6 Cut-off current characteristics.....	171
7.7 I^2t characteristics	171
7.8 Overcurrent discrimination.....	172
7.9 Protection against electric shock	172
8 Tests	172
8.3 Verification of temperature rise and power dissipation.....	172
8.3.1 Arrangement of the fuse	172
8.4 Verification of operation	173
8.4.1 Arrangement of the fuse	173
8.5.4 Recovery voltage.....	173
8.6 Verification of cut-off current characteristics	173
8.7 Verification of I^2t characteristics and overcurrent discrimination.....	174
8.9 Verification of resistance to heat	175
8.10 Verification of non-deterioration of contacts.....	175
8.10.1 Arrangement of the fuse	175
8.10.2 Test method	175
8.10.3 Acceptability of test results	175
8.11 Mechanical and miscellaneous tests.....	175
8.11.2 Miscellaneous tests	176
FIGURES.....	177

Fuse system K – gK fuse-links with blade contacts for bolted connections – High current fuse-link ratings from 1 250 A up to 4 800A (Master fuse-links).....	186
1 General	186
1.1 Scope.....	186
2 Terms and definitions	186
3 Conditions for operation in service.....	186
3.9 Discrimination of fuse-links.....	186
4 Classification.....	186
5 Characteristics of fuses	186
5.2 Rated voltage	187
5.3.1 Rated current of the fuse-link.....	187
5.3.2 Rated current of the fuse-holder	187
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	187
5.6 Limits of the time-current characteristics	187
5.6.1 Time-current characteristics, time-current zones	187
5.6.2 Conventional times and currents.....	188
5.6.3 Gates	188
5.7.2 Rated breaking capacity	188
6 Markings	188
6.2 Markings of fuse-links.....	189
7 Standard conditions for construction.....	189
7.1 Mechanical design.....	189
7.1.3 Fuse-contacts.....	189
7.6 Cut-off current characteristics.....	189
7.7 I^2t characteristics	189
7.8 Over-current selectivity of "gK" fuse-links	189
7.9 Protection against electric shock	189
8 Tests	190
8.3 Verification of temperature rise and power dissipation.....	190
8.3.1 Arrangement of the fuse	190
8.4.1 Arrangement of the fuse	190
8.6 Verification of cut-off current characteristics	190
8.7 Verification of I^2t characteristics and over-current selectivity	191
8.9 Verification of resistance to heat	191
8.10 Verification of non-deterioration of contacts.....	192
8.10.1 Arrangement of the fuse	192
8.10.2 Test method	192
8.10.3 Acceptability of test results	192
FIGURES.....	193
Bibliography.....	200
Figure 101 – Fuse-links with blade contacts (1 of 3)	41
Figure 102 – Fuse-bases for fuse-links with blade contacts	44
Figure 103 – Replacement handle.....	45
Figure 104 – Time-current zones for "gG" fuse-links (1 of 5)	46
Figure 105 – Dummy fuse-link according to 8.3.4.1, 8.9.1 and 8.10	51

Figure 106 – Measuring points according to 8.3.4 of IEC 60269-1, 8.3.4.1, 8.3.4.2 and 8.10.2 of fuse system A	52
Figure 107 – Test knife according to 8.5.5.1.2	52
Figure 108 – Example of a measuring device for determining the withdrawal forces according to 8.9.1 and 8.11.1.2.....	53
Figure 109 – Facility for verifying the mechanical strength of gripping-lugs (see 8.11.1.8).....	54
Figure 110 – Measuring points according to 8.10.2	55
Figure 111 – Reference fuse-base	56
Figure 112 – Design mark for isolated gripping-lugs.....	57
Figure 201 – Fuse-links with blade contacts with striker (1 of 4).....	64
Figure 202 – Fuse-bases for fuse-links with blade contacts with striker (1 of 3)	68
Figure 301 – Fuse-rails for fuse-links with blade contacts (1 of 3)	76
Figure 302 – Test arrangement for fuse-rails (1 of 2)	79
Figure 401 – Busbar mounting bases, 1 pole	86
Figure 402 – Busbar mounting bases, 3 pole	87
Figure 403 – Busbar mounting base, size 00, 2 × 3 pole (tandem fuse-base)	88
Figure 404 – Test arrangement for single-pole and triple-pole fuse-bases for busbar-mounting according to 8.3.1.....	89
Figure 405 – Test arrangement for two single-pole and six single-pole fuse-bases in tandem arrangement for busbar-mounting according to 8.3.1.....	90
Figure 406 – Test arrangement for the verification of the peak withstand current	91
Figure 407 – Dummy fuse-link	92
Figure 501 – Fuse-links for bolted connection – Sizes A, B, C and D (1 of 2)	98
Figure 502 – Typical fuse-holder (1 of 2).....	100
Figure 503 – Time-current zones for "gG" fuse-link	102
Figure 504 – Time-current zones for "gG" fuse-link	103
Figure 505 – Power dissipation test rig	104
Figure 506 – Breaking capacity test rig for fuse-links for bolted connection (1 of 2)	105
Figure 601 – Fuse-links with cylindrical caps	118
Figure 602 – Fuse-links with cylindrical contact caps with striker – Additional dimensions for sizes 14 × 51 and 22 × 58 only	119
Figure 603 – Base for fuse-links with cylindrical caps (1 of 2)	120
Figure 701 – Fuse-links having offset blade contacts, sizes E1, F1, F2 and F3	128
Figure 702 – Typical fuse-holder	129
Figure 703 – Time-current zones for "gG" fuse-links	130
Figure 704 – Time-current zones for "gG" fuse-links	131
Figure 705 – Power dissipation test rig	132
Figure 801 – Class J fuse-links (1 A to 600 A)	142
Figure 802 – Class L fuse-links (700 A to 6 000 A)	143
Figure 803 – Fuse-base and contacts for class J fuse-links 1 A to 600 A	144
Figure 804 – Fuse-base and contacts for class L fuse-links 700 A to 6 000 A	145
Figure 805 – Class T fuse-links (1 A to 1 200 A)	146
Figure 806 – Fuse-base and contacts for class T fuse-links 1 A to 1 200 A	147
Figure 807 – Temperature test arrangement	148

Figure 808 – Time-current zones for "gN" fuse-links	149
Figure 809 – Time-current zones for "gN" fuse-links	150
Figure 810 – Time-current zones for "gN" fuse-links	151
Figure 811 – Time-current zones for "gD" fuse-links	152
Figure 812 – Time-current zones for "gD" fuse-links	153
Figure 813 – Time-current zones for "gD" fuse-links	154
Figure 901 – Time-current zones for current ratings 100 A, 200 A, 355 A and 630 A	161
Figure 902 – Time-current zones for current ratings 160 A and 315 A	162
Figure 903 – Time-current zones for current ratings 250 A and 500 A	163
Figure 904 – Time-current zones for current ratings 200 A and 400 A	164
Figure 905 – Dimensions for fuse-links with L type and U type tags	165
Figure 906 – Power dissipation test rig	166
Figure 907 – Breaking capacity test rig (1 of 2)	167
Figure 1001 – Class CC fuse-links (1 A to 30 A)	177
Figure 1002 – Fuse-base and contacts for class CC fuse-links 1 A to 30 A	177
Figure 1003 – Class CC dummy fuse-link dimensions	178
Figure 1004 – Temperature test arrangement	179
Figure 1005 – Time-current zones for class CC "gN" fuses	180
Figure 1006 – Time-current zones for class CC "gN" fuses	181
Figure 1007 – Time-current zones for class CC "gN" fuses	182
Figure 1008 – Time-current zones for class CC "gD" fuses	183
Figure 1009 – Time-current zones for class CC "gD" fuses	184
Figure 1010 – Time-current zones for class CC "gD" fuses	185
Figure 1101 – "gK" fuse-links (1 of 2)	193
Figure 1102 – Connecting dimensions for "gK" fuse-links (1 of 3)	195
Figure 1103 – Dummy fuse-link	197
Figure 1104 – Time-current zones for "gK" fuse system K (1 of 2)	198
 Table 101 – Conventional time and current for "gG" fuse-links with rated current lower than 16 A	22
Table 102 – Gates for specified pre-arching and operating times of "gG" fuse-links	22
Table 103 – Minimum rated breaking capacities	22
Table 104 – Marking of fuse-links	23
Table 105 – Minimum cross-sectional ranges of unprepared conductors	24
Table 106 – Pre-arching and operating I^2t values at 0,01 s for "gG" fuse-links	25
Table 107 – Maximum operating I^2t values for "aM" fuse-links	25
Table 108 – Pre-arching I^2t values for discrimination of gG fuse-links	26
Table 109 – Survey of tests on fuse-holders and number of fuse-holders to be tested	27
Table 110 – Rated impulse withstand voltage	27
Table 111 – Torque to be applied to the terminal screws	28
Table 112 – Test currents	29
Table 113 – Test currents and I^2t limits for selectivity test	31
Table 114 – Torques to be applied when no values are given by the manufacturer	34

Table 115 – Cross-sectional area of aluminium conductors for tests corresponding to 8.10	34
Table 116 – Test sequence for direct terminal clamps.....	36
Table 117 – Permissible changes of the resistance.....	37
Table 118 – Force to withdraw the fuse-link from the fuse-base contacts	38
Table 201 – Position and force of the striker	61
Table 301 – Minimum cross-sectional ranges of unprepared conductors for fuse-rails.....	72
Table 302 – Survey of complete tests on fuse-rails and number of fuse-rails to be tested	73
Table 401 – Minimum cross-sectional ranges of unprepared conductors for fuse-bases for busbar mounting.....	82
Table 402 – Torques to be applied to contact making screws.....	83
Table 403 – Test currents	84
Table 404 – Force to withdraw the fuse-link from the fuse-base contacts	85
Table 501 – Conventional time and current for "gG" fuse-links	94
Table 502 – Gates for specified pre-arcing times of "gG" fuse-links	94
Table 601 – Maximum rated current of fuse-links with cylindrical caps	108
Table 602 – Maximum rated current of fuse-holders.....	108
Table 603 – Maximum values of the rated power dissipation of a fuse-link	109
Table 604 – Rated acceptable power dissipation of a fuse-holder	109
Table 605 – Conventional time and current for "gG" fuse-links with rated current lower than 16 A	110
Table 606 – Gates for specified pre-arcing and operating times of "gG" fuse-links with rated current lower than 16 A.....	110
Table 607 – Minimum rated breaking capacities.....	110
Table 608 – Marking of fuse-links	111
Table 609 – Minimum range of cross-sections for rigid copper conductors	111
Table 610 – Pre-arcing and operating i^2t values at 0,01 s for "gG" fuse-links	112
Table 611 – Maximum operating i^2t values for "aM" fuse-links	112
Table 612 – Survey of tests on fuse-holders and number of fuse-holders to be tested	113
Table 613 – Torque to be applied to the terminal screws	113
Table 614 – Test currents	114
Table 615 – Test currents and i^2t limits for discrimination test.....	116
Table 701 – Conventional time and current for "gG" fuse-links	123
Table 702 – Gates for specified pre-arcing times of "gG" fuse-links	124
Table 703 – Sizes of copper conductors	125
Table 704 – Pre-arcing i^2t values at 0,01 s for "gG" fuse-links	125
Table 801 – Conventional time and current for "gD" and "gN" fuse-links	134
Table 802 – Gates for specified pre-arcing times of "gD" and "gN" fuse-links	135
Table 803 – Pre-arcing i^2t values at 0,01 s for "gD" and "gN" fuse-links	136
Table 804 – Cross-sectional area of copper conductors for tests corresponding to 8.3 and 8.4	137
Table 805 – Class J dummy fuse-link dimensions	138
Table 806 – Class T dummy fuse-link dimensions	138

Table 807 – Maximum cut-off current (I_C) for "gD" and "gN" fuse-links at 200 kA prospective current	139
Table 808 – Maximum operating I^2t values for "gD" and "gN" fuse-links at 200 kA prospective current	140
Table 901 – Maximum power dissipation values	156
Table 902 – Pre-arcing I^2t values for gU fuse-links at 0,01 s	158
Table 903 – Cross-sectional area of conductors for power dissipation and temperature-rise tests	159
Table 1001 – Conventional time and current for "gD class CC" and "gN class CC" fuse-links	170
Table 1002 – Gates for specified pre-arcing times of "gD class CC" and "gN class CC" fuse-links	170
Table 1003 – Pre-arcing I^2t values at 0,01 s for "gD class CC" and "gN class CC" fuse-links	172
Table 1005 – Maximum cut-off current (I_C) for "gD class CC" and "gN class CC" fuse-links at 200 kA prospective current	174
Table 1006 – Maximum operating I^2t values for "gD class CC" and "gN class CC" fuse-links at 200 kA prospective current	174
Table 1101 – Maximum power dissipation values for «gK» fuse-links	187
Table 1102 – Conventional time and current for «gK» fuse-links	188
Table 1103 – Gates for specified pre-arcing and operating times of "gK" fuse-links	188
Table 1104 – Minimum rated breaking capacities for "gK" fuse-links	188
Table 1105 – Pre-arcing and operating I^2t values at 0,01 s for "gK" fuse-links	189
Table 1106 – Cross-sectional area of copper conductors for tests corresponding to 8.3 and 8.4	190
Table 1107 – Maximum cut-off current (I_C) for "gK" fuse-links (1 250 A to 4 800 A) at 100 kA prospective current	191
Table 1108 – Test currents and I^2t limits for "gK" fuse-links selectivity test	191

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60269-2 edition 5.2 contains the fifth edition (2013-07) [documents 32B/611/FDIS and 32B/615/RVD], its amendment 1 (2016-08) [documents 32B/641/CDV and 32B/648/RVC] and its amendment 2 (2024-06) [documents 32B/743/FDIS and 32B/755/RVD] and its corrigendum 1 (2025-06).

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60269-2 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

This edition includes the following significant technical changes with respect to the previous edition:

- a) fuse systems A and B: modified values for the power dissipation of NH aM fuse-links;
- b) fuse systems A and B: introduction of dimension r for NH fuse-links;
- c) addition of new fuse system K: gK fuse-links with contacts for bolted connections.

This part is to be used in conjunction with IEC 60269-1:2006, *Low-voltage fuses – Part 1: General requirements* and its Amendment 1 (2009).

This Part 2 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 2 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 101 in fuse system A, from 201 in fuse system B, etc. Additional annexes are numbered AA, BB, etc.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60269 series, published under the general title *Low-voltage fuses*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendments will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

- Part 1: General requirements
- Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K
- Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F
- Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices
- Part 5: Guidance for the application of low-voltage fuses
- Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

1 General scope

1.1 Scope

Fuses for use by authorized persons are generally designed to be used in installations where the fuse-links are accessible to, and may be replaced by, authorized persons only.

Fuses for use by authorized persons according to the following fuse systems also comply with the requirements of the corresponding subclauses of IEC 60269-1, unless otherwise defined in this standard.

This standard is divided into fuse systems, each dealing with a specific example of standardized fuses for use by authorized persons:

- Fuse system A: Fuses with fuse-links with blade contacts (NH fuse system)
- Fuse system B: Fuses with striker fuse-links with blade contacts (NH fuse system)
- Fuse system C: Fuse-rails (NH fuse system)
- Fuse system D: Fuse-bases for busbar mounting (NH fuse system)
- Fuse system E: Fuses with fuse-links for bolted connections (BS bolted fuse system)
- Fuse system F: Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)
- Fuse system G: Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)
- Fuse system H: Fuses with fuse-links having "gD" and "gN" characteristic (class J class L and class T time delay and non time delay fuse types)
- Fuse system I: gU fuse-links with wedge tightening contacts
- Fuse system J: Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)
- Fuse system K: gK fuse-links with blade for bolted connections – High fuse-link ratings from 1 250 A up to 4 800 A (master fuse-links)

NOTE The above-mentioned fuse systems are standardized systems in respect to their safety aspects. The National Committees can select from the examples of standardized fuses one or more systems for their own standards.

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60269-1, *Low-voltage fuses – Part 1: General requirements*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60999 (all parts), *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 60999-2, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 2: Particular requirements for clamping units for conductors above 35 mm² up to 300 mm² (included)*

ISO 22479, *Corrosion of metals and alloys – Sulfur dioxide test in a humid atmosphere (fixed gas method)*