



IEC 60730-2-6

Edition 4.0 2025-08

INTERNATIONAL STANDARD

**Automatic electrical controls -
Part 2-6: Particular requirements for automatic electrical pressure sensing
controls including mechanical requirements**

CONTENTS

FOREWORD	3
1 Scope	6
2 Normative references	7
3 Terms and definitions	7
4 General	8
5 Required technical information	9
6 Protection against electric shock	10
7 Provision for protective earthing	10
8 Terminals and terminations	10
9 Constructional requirements	10
10 Threaded parts and connections	12
11 Creepage distances, clearances and distances through solid insulation	12
12 Components	12
13 Fault assessment on electronic circuits	12
14 Moisture and dust resistance	12
15 Electric strength and insulation resistance	12
16 Heating	12
17 Manufacturing deviation and drift	13
18 Environmental stress	13
19 Endurance	13
20 Mechanical strength	14
21 Resistance to heat, fire and tracking	15
22 Resistance to corrosion	15
23 Electromagnetic compatibility (EMC) requirements - Emission	15
24 Normal operation	15
25 Electromagnetic compatibility (EMC) requirements - Immunity	16
26 Abnormal operation tests	16
Annex H (normative) Requirements related to functional safety	17
Annex Q (informative) Regional differences relevant for the member countries of Cenelec	28
Annex R (informative) National differences relevant in the United States of America	29
Annex S (informative) National differences relevant in Japan	30
Annex T (informative) National differences relevant in Canada	31
Annex AA (normative) Number of cycles	32
Annex BB (informative) Stainless steel for bellows, bourdon tubes or similar elements	33
Bibliography	36

Table 1 – Required technical information and methods of providing these information	9
Table H.1 – Additional items to Table 1.....	17
Table AA.1 – Number of cycles for independently mounted controls	32
Table AA.2 – Cycling rate for independently mounted controls.....	32
Table BB.1 - Stainless steel for bellows, bourdon tubes or similar elements.....	33

INTERNATIONAL ELECTROTECHNICAL COMMISSION

Automatic electrical controls - Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-2-6 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2015 and its Amendment 1:2019. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

Adoption of IEC 60730-1:2022 with all of its significant changes to IEC 60730-1:2013, IEC 60730-1:2013/AMD 1:2015 and IEC 60730-1:2013/AMD2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1486/FDIS	72/1504/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

This part 2-6 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the sixth edition of that standard (2022). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This part 2-6 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert that publication into the IEC standard: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements.

Where this part 2-6 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The reader's attention is drawn to the fact that Annex Q, Annex R, Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

In this publication:

The following print types are used:

- requirements proper: in roman type;
- *test specifications*: in italic type;
- explanatory matter: in smaller roman type;
- defined terms: **bold type**.

Subclauses, notes or items which are additional to those in Part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

1 Scope

This clause of Part 1 is replaced by the following:

This document applies to **automatic electrical pressure sensing controls**

- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment" and "controls" means "pressure **sensing controls**".

- for building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);

EXAMPLE 1 Independently mounted **automatic electrical pressure sensing controls**, controls in smart grid systems and controls for building automation systems within the scope of ISO 16484-2.

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 2 **Automatic electrical pressure sensing controls** for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled automatic electrical pressure sensing controls**;

EXAMPLE 3 Smart grid **automatic electrical pressure sensing controls**, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling a pressure or vacuum;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document is also applicable to individual pressure **sensing controls** utilized as part of a **control system** or pressure **sensing controls** which are mechanically integral with multi-functional controls having non-electrical outputs.

This document is also applicable to pressure **sensing controls** for appliances within the scope of IEC 60335-1.

This document applies to

- the inherent safety of pressure **sensing controls**, and
- functional safety of pressure **sensing controls** and safety related systems,
- pressure **sensing controls** where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
- the operating values, operating times, and operating sequences where such are associated with equipment safety.

This document specifies the requirements for construction, operation and testing of automatic electrical controls used in, on, or in association with an equipment.

This document does not

- apply to pressure **sensing controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate automatic electrical controls intended specifically for industrial applications in cases where no relevant safety standard exists;
- take into account the response value of an automatic action of a pressure **sensing control**, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply;
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

This document contains requirements for electrical features of pressure **sensing controls** and requirements for mechanical features that affect their intended **operation**.

NOTE Subclause 20.101, as it pertains to gas and/or oil controls, is under consideration pending review or revision of ISO 22967, ISO 22968 and ISO 23550, if applicable.

In general, these pressure **sensing controls** are integrated or incorporated with the equipment or are intended to be integrated in, or on the equipment. This document also covers these controls when they are independently mounted. **In-line cord controls** are not covered by this document.

2 Normative references

This clause of Part 1 is applicable.