

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage switchgear and controlgear –
Part 4-1: Contactors and motor-starters – Electromechanical contactors and
motor-starters**

**Appareillage à basse tension –
Partie 4-1: Contacteurs et démarreurs de moteurs – Contacteurs et démarreurs
électromécaniques**



IEC 60947-4-1

Edition 5.0 2023-11

Corrected version
2026-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage switchgear and controlgear –
Part 4-1: Contactors and motor-starters – Electromechanical contactors and
motor-starters**

**Appareillage à basse tension –
Partie 4-1: Contacteurs et démarreurs de moteurs – Contacteurs et démarreurs
électromécaniques**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.99, 29.130.20

ISBN 978-2-8322-7773-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	10
1 Scope.....	13
2 Normative references	14
3 Terms, definitions, symbols and abbreviated terms.....	15
3.1 General.....	15
3.2 Alphabetical index of terms	15
3.3 Terms and definitions concerning contactors	18
3.4 Terms and definitions of the functions of starters	19
3.5 Terms and definitions concerning starters	20
3.6 Terms and definitions concerning characteristic quantities.....	26
3.7 Terms and definitions concerning safety aspects	28
3.8 Terms and definitions concerning electric motor characteristics	31
3.9 Symbols and abbreviated terms	31
4 Classification.....	32
5 Characteristics of contactors and starters	33
5.1 Summary of characteristics	33
5.2 Type of equipment	33
5.2.1 Kind of equipment.....	33
5.2.2 Number of poles	34
5.2.3 Kind of current (AC or DC).....	34
5.2.4 Interrupting medium (air, oil, gas, vacuum, etc.)	34
5.2.5 Operating conditions of the equipment.....	34
5.2.6 Methods of overload protection of motors	34
5.3 Rated and limiting values for main circuits	35
5.3.1 Rated voltages	35
5.3.2 Currents or powers	36
5.3.3 Rated frequency	38
5.3.4 Rated duties	38
5.3.5 Normal load and overload characteristics	39
5.3.6 Short-circuit characteristics	41
5.3.7 Pole impedance of a contactor (Z) or starter	41
5.4 Utilization category	41
5.4.1 General	41
5.4.2 Assignment of utilization categories based on the results of tests	42
5.5 Control circuits.....	43
5.6 Auxiliary circuits.....	44
5.7 Characteristics of relay and release of overload relays and of motor protective switching device (MPSD)	44
5.7.1 Summary of characteristics.....	44
5.7.2 Types of relay or release	44
5.7.3 Characteristic values	45
5.7.4 Designation and current settings of overload relays	46
5.7.5 Time-current characteristics of overload relays	47
5.7.6 Influence of ambient air temperature.....	47
5.8 Co-ordination with short-circuit protective devices.....	47
5.9 Void.....	47

5.10	Types and characteristics of automatic change-over devices and automatic acceleration control devices	47
5.10.1	Types	47
5.10.2	Characteristics.....	47
5.11	Types and characteristics of auto-transformers for two-step auto-transformer starters	48
5.12	Types and characteristics of starting resistors for rheostatic rotor starters	48
6	Product information	49
6.1	Nature of information	49
6.1.1	Identification.....	49
6.1.2	Characteristics, basic rated values and utilization.....	49
6.2	Marking.....	51
6.3	Instructions for installation, operation, maintenance, decommissioning and dismantling	52
6.4	Environmental information	52
6.5	Instruction for equipment capable to be reused, repaired and upgraded.....	53
7	Normal service, mounting and transport conditions	53
8	Constructional and performance requirements	53
8.1	Constructional requirements	53
8.1.1	General	53
8.1.2	Materials	54
8.1.3	Current-carrying parts and their connections	54
8.1.4	Clearances and creepage distances	54
8.1.5	Actuator.....	55
8.1.6	Indication of the contact position	55
8.1.7	Additional requirements for equipment suitable for isolation.....	55
8.1.8	Terminals	56
8.1.9	Additional requirements for equipment provided with a neutral pole	56
8.1.10	Provisions for protective earthing.....	56
8.1.11	Enclosures for equipment	56
8.1.12	Degrees of protection of enclosed equipment	56
8.1.13	Conduit pull-out, torque and bending with metallic conduits	56
8.1.14	Limited energy source	57
8.1.15	Stored charge energy circuit.....	59
8.1.16	Fault and abnormal conditions	59
8.1.17	Short-circuit and overload protection of ports.....	60
8.1.18	Use of voltage transient limiting device	60
8.2	Performance requirements	60
8.2.1	Operating conditions.....	60
8.2.2	Temperature-rise	66
8.2.3	Dielectric properties.....	69
8.2.4	Normal load and overload performance requirements	70
8.2.5	Co-ordination with short-circuit protective devices	75
8.3	Electromagnetic compatibility (EMC).....	77
8.3.1	General	77
8.3.2	Immunity.....	78
8.3.3	Emission.....	78
8.4	Embedded software	79
8.5	Security	79

9	Tests	79
9.1	Kinds of test.....	79
9.1.1	General	79
9.1.2	Type tests.....	79
9.1.3	Routine tests	79
9.1.4	Sampling tests.....	80
9.1.5	Special tests.....	80
9.2	Compliance with constructional requirements.....	81
9.2.1	General	81
9.2.2	Electrical performance of screwless-type clamping units.....	81
9.2.3	Ageing test for screwless-type clamping units.....	82
9.2.4	Limited energy source test.....	82
9.2.5	Breakdown of components.....	83
9.2.6	Wire flexing test.....	83
9.3	Compliance with performance requirements.....	84
9.3.1	Test sequences	84
9.3.2	General test conditions.....	84
9.3.3	Performance under no load, normal load and overload conditions.....	85
9.3.4	Performance under short-circuit conditions	98
9.3.5	Overload current withstand capability of contactors and IMPSDs.....	104
9.3.6	Routine tests and sampling tests	104
9.4	EMC tests	106
9.4.1	General	106
9.4.2	Immunity.....	106
9.4.3	Emission.....	108
Annex A (normative) Marking and identification of terminals of contactors, starters and associated overload relays.....		110
A.1	General.....	110
A.2	Marking and identification of terminals of main circuits.....	110
A.3	Marking and identification of terminals of overload relays	110
Annex B (normative) Special tests		112
B.1	General.....	112
B.2	Mechanical durability	112
B.2.1	General	112
B.2.2	Verification of mechanical durability.....	112
B.3	Electrical durability	114
B.3.1	General	114
B.3.2	Results to be obtained	115
B.3.3	Statistical analysis of test results for contactors or starters.....	115
B.4	Co-ordination at the crossover current between the starter and associated SCPD	116
B.4.1	General	116
B.4.2	Condition for the test for the verification of co-ordination at the crossover current by a direct method	116
B.4.3	Test currents and test circuits.....	116
B.4.4	Test procedure and results to be obtained	117
B.4.5	Verification of co-ordination at the crossover current by an indirect method	117

Annex C (informative) Electric motor evolutions and motor starting methods.....	120
C.1 General.....	120
C.1.1 Major changes on the market concerning electrical motors	120
C.1.2 Electric motor characteristics	121
C.1.3 Efficiency motor analysis	121
C.1.4 Impacts on switchgear and controlgear	123
C.2 Typical variants direct-on-line starters.....	123
C.3 Functional aspects of motor starters	126
C.4 Currents and torques during a star-delta start	128
C.5 Currents and torques during an auto-transformer start	131
C.6 Currents waveform of the different modes of operation of a starter	133
Annex D (informative) Items subject to agreement between manufacturer and user	135
Annex E (Void)	136
Annex F (normative) Requirements for auxiliary contact linked with power contact (mirror contact).....	137
F.1 Application and object.....	137
F.1.1 Application.....	137
F.1.2 Object.....	137
F.2 Characteristics.....	137
F.3 Product information.....	137
F.4 Normal service, mounting and transport conditions	138
F.5 Constructional and performance requirements	138
F.6 Tests	138
F.6.1 General	138
F.6.2 Tests on products in a new condition	138
F.6.3 Test after conventional operational performance (defined under Table 10).....	139
Annex G (informative) Rated operational currents and rated operational powers of switching devices for electrical motors	140
G.1 General.....	140
G.2 Rated operational powers and rated operational currents.....	140
Annex H (normative) Extended functions to electronic overload relays.....	144
H.1 General.....	144
H.2 Limits of operation of control functions	144
H.2.1 General	144
H.2.2 Limits of electronic overload relay with main circuit undervoltage restarting function.....	144
H.3 Test of the control functions	144
Annex I (informative) AC-1 contactors for use with semiconductor controlled motor load	145
Annex J (Void).....	146
Annex K (normative) Procedure to determine data for electromechanical contactors used in functional safety applications.....	147
K.1 General.....	147
K.2 Test requirements	147
K.3 Characterization of a failure mode	147
K.4 Failure ratios of a contactor	147

Annex L (normative) Assessment procedure for electromechanical overload protection used in safety applications and especially in explosive atmospheres	149
L.1 Application and object.....	149
L.1.1 Application.....	149
L.1.2 Object.....	149
L.2 Procedure	149
L.2.1 General	149
L.2.2 Safety design process	150
L.3 Requirements	150
L.3.1 General	150
L.3.2 Safety plan	150
L.3.3 Design	151
L.3.4 Failure mode and effects analysis of the safety function	151
L.3.5 Design plan	152
L.3.6 Verification	152
L.3.7 Function assessed.....	152
L.4 Documentation.....	152
L.4.1 Technical safety documentation.....	152
L.4.2 Safety instructions	152
L.5 Example.....	153
L.5.1 architecture description	153
L.5.2 FMEA	154
Annex M (normative) DC contactors for use in photovoltaic (PV) applications	162
M.1 Application	162
M.2 Object.....	162
M.3 Classification	162
M.4 Characteristics.....	162
M.4.1 General	162
M.4.2 Rated impulse withstand voltage.....	162
M.4.3 Utilization category	163
M.5 Product information.....	163
M.6 Normal service, mounting and transport conditions	164
M.6.1 General	164
M.6.2 Ambient air temperature	164
M.6.3 Altitude	164
M.7 Constructional and performance requirements	164
M.7.1 Constructional requirements	164
M.7.2 Performance requirements.....	164
M.7.3 Electromagnetic compatibility (EMC)	165
M.8 Tests	166
M.8.1 General	166
M.8.2 Type tests.....	166
M.8.3 Making and breaking capacities and conventional operational performance	166
M.8.4 Thermal cycling test.....	166
M.8.5 Climatic test.....	167
M.8.6 Dielectric test	167
M.8.7 Critical load current test.....	167
M.8.8 Mechanical and electrical properties of terminals.....	168

M.8.9	Degree of protection of enclosed contactors	168
M.8.10	EMC	168
M.8.11	Clearance and creepage distances	168
Annex N (normative)	Additional requirements and tests for equipment with protective separation.....	169
N.1	General.....	169
N.2	Terms and definitions.....	169
N.3	Requirements	169
N.3.1	Test method for implementing protective impedance.....	169
N.3.2	Touch current measurement	170
Annex O (normative)	Load monitoring indicators	172
O.1	General.....	172
O.2	Indicators list	172
O.3	Uncertainty	174
O.4	Tests	175
O.4.1	Routine tests	175
O.4.2	Type tests.....	175
Annex P (normative)	Short-circuit breaking tests of MPSD.....	177
P.1	General test conditions	177
P.2	Rated service short-circuit breaking capacity	178
P.2.1	General	178
P.2.2	Test of rated service short-circuit breaking capacity.....	178
P.2.3	Verification of operational performance capability	178
P.2.4	Verification of dielectric withstand.....	178
P.2.5	Verification of temperature-rise.....	179
P.2.6	Verification of overload releases	179
P.3	Rated ultimate short-circuit breaking capacity	179
P.3.1	General	179
P.3.2	Verification of overload releases	179
P.3.3	Test of rated ultimate short-circuit breaking capacity	180
P.3.4	Verification of dielectric withstand.....	180
P.3.5	Verification of overload releases	180
P.4	Test of MPSD for IT system	180
P.4.1	General	180
P.4.2	Individual pole short-circuit	181
P.4.3	Verification of dielectric withstand.....	181
P.4.4	Verification of overload releases	181
P.4.5	Marking	182
Bibliography.....		183
Figure 1 – Multiple of current setting limits for ambient air temperature compensated time-delay overload relays		63
Figure 2 – Thermal memory test		64
Figure 3 – Example of different parts		67
Figure 4 – Examples of co-ordination characteristics of a starter.....		77
Figure 5 – Voltage drop measurement at contact point of the clamping terminal		82
Figure 6 – Peak current envelope		89
Figure A.1 – Main circuit		110

Figure A.2 – Overload relays	111
Figure B.1 – Examples of time-current withstand characteristic.....	119
Figure C.1 – Electric motor characteristics.....	121
Figure C.2 – Rated current of different energy efficiency classes	122
Figure C.3 – Ratio of the rated locked-rotor current to the nominal current.....	122
Figure C.4 – Ratio of the inrush current to the nominal current	123
Figure C.5 – Connections to motor windings	124
Figure C.6 – Current and torque during direct-on-line starting.....	125
Figure C.7 – Typical variants of protected starters, combination starters, protected switching devices and combination switching devices	126
Figure C.8 – Functional view of motor starters	127
Figure C.9 – Motor overload protection embedded into a circuit-breaker.....	128
Figure C.10 – Typical curves of currents and torques during a star-delta start	129
Figure C.11 – Timing of star-delta-switching	130
Figure C.12 – Typical method and diagram of starting alternating-current induction motors by means of star-delta starter.....	131
Figure C.13 – Typical curves of currents and torques during an auto-transformer starting of a motor.....	132
Figure C.14 – Typical schematic diagrams for starting alternating-current induction motors by means of auto-transformers.....	133
Figure C.15 – Examples of current and time curves of motor starting and stopping in one or two directions.....	134
Figure F.1 – Mirror contact.....	138
Figure L.1 – Safety design process	150
Figure L.2 – Typical structure of a thermal overload relay	153
Figure L.3 – typical structure of MPSD	154
Figure N.1 – Protection by means of protective impedance	170
Figure N.2 – Measuring instrument	171
Figure O.1 – Example of quantification of a process change	174
Table 1 – Utilization categories	43
Table 2 – Trip classes of overload relays	46
Table 19 – Limits for limited energy sources without an overcurrent protective device	58
Table 20 – Limits for limited energy sources with an overcurrent protective device	58
Table 21 – Limits for limited energy source with current limiting impedance	59
Table 3 – Limits of operation of time-delay overload relays when energized on all poles.....	63
Table 4 – Limits of operation of three-pole time-delay overload relays when energized on two poles only.....	65
Table 5 – Temperature-rise limits for insulated coils in air and in oil	66
Table 6 – Intermittent duty test cycle data.....	69
Table 7 – Making and breaking capacities – Making and breaking conditions according to utilization category.....	70
Table 8 – Relationship between the test current and off-time for the verification of rated making and breaking capacities	72
Table 9 – Operational current determination for utilization categories AC-6a and AC-6b when derived from AC-3 ratings	72

Table 10 – Conventional operational performance – Making and breaking conditions according to utilization category	73
Table 11 – Overload current withstand requirements	74
Table 12 – Specific acceptance criteria for immunity tests	78
Table 13 – Value of the prospective test current according to the rated operational current	101
Table 14 – Value of the conventional prospective test current according to the rated operational current (harmonized table)	101
Table 15 – Test conditions for I_{Cd}	104
Table 16 – EMC immunity tests	107
Table 17 – Terminal disturbance voltage limits for conducted radio-frequency emission (for mains ports)	109
Table 18 – Radiated emission test limits	109
Table B.1 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to the several utilization categories	115
Table B.2 – Test conditions	118
Table F.1 – Test voltage according to altitude	139
Table G.1 – Rated operational powers and rated operational currents of motors	141
Table K.1 – Failure mode of contactors	147
Table K.2 – Typical failure ratios for normally open contactors	148
Table L.1 – Severity	154
Table L.2 – Occurrence	155
Table L.3 – Detection levels	155
Table L.4 – Conclusion	156
Table L.5 – Example of failure mode and effects analysis for thermal overload relay	157
Table M.1 – Rated impulse voltage levels for PV contactors	163
Table M.2 – Utilization categories	163
Table M.3 – Ambient air temperature conditions	164
Table M.4 – Verification of rated making and breaking capacities – Conditions for making and breaking corresponding to the DC-PV category	165
Table M.5 – Conventional operational performance – Making and breaking condition corresponding to the DC-PV category	165
Table M.6 – Overall scheme of test sequences	166
Table M.7 – Number of operating cycles corresponding to the critical load current	168
Table M.8 – Critical load current performance	168
Table O.1 – AC monitoring indicators list	173
Table O.2 – Different possibilities authorized for verification of indicators	175
Table O.3 – Reference for verification conditions	176
Table O.4 – Harmonic levels	176

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60947-4-1 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) objective in the scope;
- b) instantaneous only motor protective switching device IMPSD (3.5.33);
- c) kinds of equipment (5.2.1);

- d) methods of overload protection of motors (5.2.6);
- e) adoption of the AC-7d from IEC 61095:2023 (in 5.4.2);
- f) separately mounted overload relay of a starter (in 5.7.3 b));
- g) starter and contactor suitable for use downstream to basic drive module (6.1.2 w));
- h) reference to IEC TS 63058 for environmental aspects (in 6.4);
- i) wiring subject to movement (in 8.1.3);
- j) use of voltage transient limiting device (8.1.18);
- k) accessible parts subject to temperature limits (in 8.2.2.3);
- l) reference to Annex X of IEC 60947-1:2020 for the co-ordination of MPSD with SCPD (8.2.5.4);
- m) reference to IEC TR 63216 with different EMC environments (8.3.1);
- n) reference to IEC TR 63201 for the embedded software design (8.4);
- o) reference to IEC TS 63208 for cybersecurity aspects (8.5);
- p) update and completion of the measurement method of the power consumption of the electromagnet (9.3.3.2.1.2);
- q) update of Annex C including rational about AC-3e;
- r) determination of the critical load current for photovoltaic applications (M.8.7).

The text of this International Standard is based on the following documents:

Draft	Report on voting
121A/571/FDIS	121A/580/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60947 series can be found, under the general title *Low-voltage switchgear and controlgear*, on the IEC website.

This document shall be read in conjunction with IEC 60947-1:2020, *Low voltage switchgear and controlgear – Part 1: General rules*. The provisions of the general rules are applicable to this document, where specifically called for.

The provisions of the general rules dealt with IEC 60947-1 are applicable to this part of IEC 60947 series where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to IEC 60947-1:2020. For example, 5.3.4.1 of IEC 60947-1:2020, Table 4 of IEC 60947-1:2020, or Annex A of IEC 60947-1:2020.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The content of the corrigendum 1 (2026-03) has been included in this copy.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters

1 Scope

This part of IEC 60947 is applicable to the following equipment:

- electromechanical contactors and starters including motor protective switching devices (MPSD and IMPSD);
- actuators of contactor relays;
- contacts dedicated exclusively to the coil circuit of the contactor or the contactor relay;
- dedicated accessories (e.g. dedicated wiring, dedicated latch accessory);

intended to be connected to distribution circuits, motors circuits and other load circuits, the rated voltage of which does not exceed 1 000 V AC or 1 500 V DC.

This document does not apply to:

- starters for DC motors;
- auxiliary contacts of contactors and contacts of contactor relays. These are covered by IEC 60947-5-1;
- the short-circuit protective device integrated within starters, other than MPSDs. This is covered by IEC 60947-2 and IEC 60947-3;
- motor overload protection function performed by control units for built-in thermal protection (PTC). They are covered by IEC 60947-8;
- the use of the equipment with additional measures within explosive atmospheres. These are given in IEC 60079 series;

The objective of this document is to state:

- the characteristics and composition of the equipment (Clause 5);
- the conditions applicable to the equipment with reference to:
 - its operation (5.2.5) and protection functions (5.2.6, 5.7, 5.8),
 - its intended environments (6.5, 8.3.1) and applications (5.4, Annex C, Annex D, Annex G, Annex H, Annex I, Annex M, Annex O) including safety applications (Annex F, Annex K, Annex L),
 - its construction and performance (Clause 8) including requirements to reduce risks of electric shock, thermal hazard, energy hazard, fire hazard and mechanical hazard, reasonably foreseeable misuse, electromagnetic compatibility (EMC) issues, software errors and security issues;
- the tests intended for confirming that these conditions have been met, and the methods to be adopted for these tests (Clause 9);
- the information to be included with the equipment or in the product documentation (Clause 6).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1:2022, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-12:2016, *Rotating electrical machines – Part 12: Starting performance of single-speed three-phase cage induction motors*

IEC 60034-30-1:2014, *Rotating electrical machines – Part 30-1: Efficiency classes of line operated AC motors (IE code)*

IEC 60068-2-14:2023, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60079-14, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60364-1:2005, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60715:2017, *Dimensions of low-voltage switchgear and controlgear – Standardized mounting on rails for mechanical support of switchgear, controlgear and accessories*

IEC 60730-1, *Automatic electrical controls – Part 1: General requirements*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60947-2:2016, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-5-1:2016, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 61051-2, *Varistors for use in electronic equipment – Part 2: Sectional specification for surge suppression varistors*

IEC 61095:2023, *Electromechanical contactors for household and similar purposes*

IEC 61140:2016, *Protection against electric shock – Common aspects for installation and equipment*

IEC 61439 (all parts), *Low-voltage switchgear and controlgear assemblies*

IEC 61643-331, *Components for low-voltage surge protection – Part 331: Performance requirements and test methods for metal oxide varistors (MOV)*

IEC 61800-5-1:2022, *Adjustable speed electrical power drive systems – Part 5-1: Safety requirements – Electrical, thermal and energy*

IEC 61810-1, *Electromechanical elementary relays – Part 1: General and safety requirements*

Bibliography

IEC 60050-151, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices*

IEC 60050-195, *International Electrotechnical Vocabulary (IEV) – Part 195: Earthing and protection against electric shock*

IEC 60050-421, *International Electrotechnical Vocabulary (IEV) – Part 421: Power transformers and reactors*

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses*

IEC 60050-442, *International Electrotechnical Vocabulary (IEV) – Part 442: Electrical accessories*

IEC 60050-826, *International Electrotechnical Vocabulary (IEV) – Part 826: Electrical installations*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60072-1:2022, *Rotating electrical machines – Dimensions and output series – Part 1: Frame numbers 56 to 400 and flange numbers 55 to 1080*

IEC 60079 (all parts), *Explosive atmospheres*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-29-3:2014, *Explosive atmospheres – Part 29-3: Gas detectors – Guidance on functional safety of fixed gas detection systems*

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60269-1:2006, *Low-voltage fuses – Part 1: General requirements*

IEC 60269-2:2013, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K*

IEC 60364-7-712, *Low voltage electrical installations – Part 7-712: Requirements for special installations or locations – Solar photovoltaic (PV) power supply systems*

IEC 60384-17:2019, *Fixed capacitors for use in electronic equipment – Part 17: Sectional specification – Fixed metallized polypropylene film dielectric AC and pulse capacitors*

IEC 60417, *Graphical symbols for use on equipment*, available at <http://www.graphical-symbols.info/equipment>

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage supply systems – Part 1: Principles, requirements and tests*

IEC 60721-3-3, *Classification of environmental conditions – Part 3-3: Classification of groups of environmental parameters and their severities – Stationary use at weatherprotected locations*

IEC 60812:2018, *Failure modes and effects analysis (FMEA and FMECA)*

IEC 60947-3:2020, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-4-2, *Low-voltage switchgear and controlgear – Part 4-2: Contactors and motor-starters – Semiconductor motor controllers, starters and soft-starters*

IEC 60947-6-2, *Low-voltage switchgear and controlgear – Part 6-2: Multiple function equipment – Control and protective switching devices (or equipment) (CPS)*

IEC 60947-8, *Low-voltage switchgear and controlgear – Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines*

IEC 60990:2016, *Methods of measurement of touch current and protective conductor current*

IEC 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for equipment used in power station and substation environment*

IEC 61032, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61508-2, *Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 2: Requirements for electrical/electronic/programmable electronic safety-related systems (see <http://www.iec.ch/functionalsafety>)*

IEC 61508-3, *Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 3: Software requirements (see <http://www.iec.ch/functionalsafety>)*

IEC 61508-4:2010, *Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 4: Definitions and abbreviations (see <http://www.iec.ch/functionalsafety>)*

IEC 61508-6:2010, *Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 6: Guidelines on the application of IEC 61508-2 and IEC 61508-3 (see <http://www.iec.ch/functionalsafety>)*

IEC 61557-12:2018, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 12: Power metering and monitoring devices (PMD)*

IEC 61557-12:2018/AMD1:2021

IEC 61649, *Weibull analysis*

IEC 61915-2:2011, *Low-voltage switchgear and controlgear – Device profiles for networked industrial devices – Part 2: Root device profiles for starters and similar equipment*

IEC 62061, *Safety of machinery – Functional safety of safety-related control systems*

IEC 62443 (all parts), *Security for industrial automation and control systems*

IEC 62477-1:2022, *Safety requirements for power electronic converter systems and equipment – Part 1: General*

IEC 62683-1, *Low-voltage switchgear and controlgear – Product data and properties for information exchange – Part 1: Catalogue data*

IEC 63365, *Industrial process measurement, control and automation – Digital nameplate*

IEC TR 63054, *Low-voltage switchgear and controlgear – Fire risk analysis and risk reduction measures*

IEC TR 63201:2019, *Low-voltage switchgear and controlgear – Guidance for the development of embedded software*

IEC 63404³, *Switchgear and controlgear and their assemblies for low voltage – Integration method of radiocommunication device into an equipment*

IEC Guide 104:2019, *The preparation of safety publications and the use of basic safety publications and group safety publications*

IEC Guide 117:2010, *Electrotechnical equipment – Temperatures of touchable hot surfaces*

ISO/IEC 80079-34, *Explosive atmospheres – Part 34: Application of quality systems for ex product manufacture*

ISO/IEC 14762:2009, *Information technology – Functional safety requirements for Home and Building Electronic Systems (HBES)*

ISO/IEE 82079-1:2012, *Preparation of instructions for use – Structuring, content and presentation – Part 1: General principles and detailed requirements⁴*

ISO/IEC Guide 51:2014, *Safety aspects – Guidelines for their inclusion in standards*

ISO 3534-2:2006, *Statistics – Vocabulary and symbols – Part 2: Applied statistics*

JIS C 4213: 2014, *Low-voltage three-phase squirrel-cage induction motors – Low-voltage top runner motor*

CSA C22.1, *Canadian Electrical Code*

CLC/TR 45550:2020, *Definitions related to material efficiency*

EN 45556, *General method for assessing the proportion of reused components in energy-related products*

EN 50495, *Safety devices required for the safe functioning of equipment with respect to explosion risks*

NFPA 70, *National Electrical Code*

PROFIEnergy profile test specification V1.1:2014

UL 508:2021, *Industrial control equipment*

³ Under preparation. Stage at the time of publication: IEC FDIS 63404:2023.

⁴ This publication was withdrawn and replaced with IEC/IEEE 82079-1:2019.

UL 60947-1, *Low-Voltage Switchgear and Controlgear – Part 1: General rules*

UL 60947-4-1, *Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*
