



IEC 61514

Edition 2.0 2026-06

# INTERNATIONAL STANDARD

REDLINE VERSION

**Industrial-process control systems - Methods of evaluating the performance of valve positioners with pneumatic outputs**

## CONTENTS

FOREWORD	4
1 Scope <del>and object</del>	6
2 Normative references	6
3 Terms and definitions	8
4 General conditions for tests	12
4.1 Environmental test conditions	12
4.1.1 General	12
4.1.2 <del>Recommended</del> Limits of ambient conditions for test measurements	12
4.2 Supply conditions	12
4.2.1 Reference values	12
4.2.2 Tolerances	12
5 General testing procedures	13
5.1 Test equipment	13
5.2 Test methods	13
5.3 Testing precautions	13
5.4 Basic test arrangement	14
5.4.1 General	14
5.4.2 Positioner tested independently of an actuator	14
5.4.3 Positioner tested in conjunction with an actuator	15
5.5 Initial setting-up	16
5.5.1 General	16
5.5.2 Positioner tested independently of an actuator	16
5.5.3 Positioner tested in conjunction with an actuator	16
6 Test procedures	16
6.1 Gain characteristic	16
6.1.1 General	16
6.1.2 Positioner tested independently of an actuator	17
6.1.3 Positioner tested in conjunction with an actuator	17
6.2 Travel characteristic	18
6.2.1 General	18
6.2.2 Positioner tested independently of an actuator	18
6.2.3 Positioner tested in conjunction with an actuator	18
6.3 Accuracy related terms	19
6.3.1 Inaccuracy	19
6.3.2 Measured error	19
6.3.3 Conformity error or linearity error (non-conformity/non-linearity)	19
6.3.4 Hysteresis	19
6.3.5 Repeatability error (non-repeatability)	19
6.4 Dead band	20
6.4.1 Dead band – Input path	20
6.4.2 Dead band – Travel path	23
6.5 Airflow data	24
6.5.1 Airflow characteristic	24
6.5.2 Steady-state air consumption	26
6.6 Effects of influence quantities	27
6.6.1 General	27

6.6.2	Supply pressure.....	28
6.6.3	Ambient temperature .....	28
6.6.4	Relative humidity .....	29
6.6.5	Mounting position .....	30
6.6.6	Mechanical shock .....	30
6.6.7	Vibration .....	31
6.6.8	Power-frequency magnetic field .....	32
6.6.9	Radiated electromagnetic field interference .....	33
6.6.10	Electrical fast transients (burst) .....	33
6.6.11	Surge voltage immunity .....	34
6.6.12	Series mode interference.....	35
6.7	Input over-range .....	36
6.7.1	General .....	36
6.7.2	Positioner tested independently of an actuator .....	36
6.7.3	Positioner tested in conjunction with an actuator .....	36
6.7.4	Common text for positioners tested independently of an actuator/with an actuator .....	36
6.8	Drift .....	36
6.8.1	General .....	36
6.8.2	Start-up drift .....	36
6.8.3	Long-term drift.....	37
6.9	Accelerated life test .....	37
6.9.1	Positioner tested independently of an actuator .....	37
6.9.2	Positioner tested in conjunction with an actuator .....	38
6.9.3	Common text for positioners tested in conjunction with/independently of an actuator .....	38
6.10	Dynamic response .....	38
6.10.1	General .....	38
6.10.2	General considerations .....	38
6.10.3	Basic test arrangement.....	38
6.10.4	Frequency response .....	39
6.10.5	Step response .....	40
7	Other considerations .....	42
7.1	General.....	42
7.2	Safety .....	43
7.3	Degree of protection provided by enclosures .....	43
7.4	Documentary information .....	43
7.5	Installation .....	44
7.6	Routine maintenance and adjustment .....	44
7.7	Repair.....	44
7.8	Protective finishes .....	45
7.9	Design features .....	45
7.10	Variants .....	45
7.11	Tools and equipment .....	45
8	Test report and documentation .....	45
	Bibliography.....	48
	Figure 1 – Single- and double-acting positioner/actuator.....	9

Figure 2 – Gain characteristic .....	11
Figure 3 – Basic test arrangement .....	15
Figure 4 – Typical error plot.....	23
Figure 5 – Test arrangement for measurement of airflow characteristic.....	25
Figure 6 – Typical air flow characteristic .....	26
Figure 7 – Series mode interference .....	35
Figure 8 – Simple dynamic response test arrangement .....	39
Figure 9 – Two examples of frequency response tests .....	40
Figure 10 – Two examples of responses to a step input.....	42
Table 1 – Environmental conditions .....	12
Table 2 – Typical table of errors .....	21
Table 3 – Vibration test levels.....	31
Table 4 – Document information .....	43
Table 5 – Test results to be reported .....	46

INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**Industrial-process control systems -  
Methods of evaluating the performance  
of valve positioners with pneumatic outputs**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61514:2000. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 61514 has been prepared by subcommittee 65B: Devices, of IEC technical committee 65: Industrial-process measurement and control. It is an International Standard.

This second edition cancels and replaces the first edition published in 2000. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) in 6.6.8 and Table 5, the magnetic field has been changed from 100 A/m to of 30 A/m (Mean Root Square);
- b) 6.10.4 and Figure 9 have been modified for better understandability;
- c) in 7.4, the reference to IEC 61187 has been deleted and replaced with a new Table 4: Document information.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65B/1309/FDIS	65B/1321/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

## 1 ~~Scope and object~~

This International Standard specifies tests designed to determine the static and dynamic performance of single-acting or double-acting analogue positioners. The tests ~~may be applied~~ apply to positioners which receive standard analogue input signals (as specified in IEC 60381-1, IEC 60381-2 and IEC 60382) and have a pneumatic output.

~~NOTE—For~~ Positioners with pulsed or digital input signals, ~~equivalent criteria may be applied. The methods described may not fully apply to~~ positioners with digital controllers ~~or~~ and positioners with pulsed outputs are outside the scope of this document.

Testing ~~may be~~ is conducted either on a positioner alone, independently of an actuator, or on a positioner mounted and connected to a specific actuator, as a combined unit. The text makes clear where different approaches are required.

The methods of evaluation given in this document are intended for use by manufacturers to determine the performance of their products, and by users, or independent testing establishments, to verify manufacturers' performance specifications.

~~The closest liaison should be maintained between the evaluating body and the manufacturer. Note should be taken of the manufacturer's specifications for the instrument when the test programme is being decided, and the manufacturer should be invited to comment on both the test programme and the results. His comments on the results should be included in any report produced by the testing organization.~~

The closest liaison between the evaluating body and the manufacturer is indispensable during the tests, including the possibility for the manufacturer to influence the test programme based on the manufacturer's specifications for the instrument and comment on both the test programme and the results.

This document is intended to provide definitions of positioner elements, actions, and characteristics, to specify uniform methods of measuring performance errors and effects of influence quantities on those characteristics, and to describe methods of reporting and evaluating the results of the measurement data obtained.

The test conditions described in this publication (for example range of ambient temperatures and power supply) relate to conditions which commonly arise in use. Consequently, the values specified ~~shall be~~ are used where no other values are specified by the manufacturer or user. If other values are used, they ~~should~~ will be stated. It is recognized that the manufacturer's specifications and instructions for installation and operation ~~should~~ apply during all steps.

The tests specified in this document are not necessarily sufficient for instruments specifically designed for unusually arduous conditions. Conversely, a reduced series of tests ~~may~~ can serve adequately for instruments designed to perform within a more limited range of conditions.

When a full evaluation, in accordance with this document, is not required or possible, ~~those~~ only the tests which are required ~~should be~~ are performed and the results reported in accordance with the relevant parts of this document. In such cases, the test report ~~should~~ will state that it does not cover the full number of tests specified herein.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 60050(161):1990, International Electrotechnical Vocabulary (IEV) — Chapter 161: Electro-magnetic compatibility~~

IEC 60050-311, *International electrotechnical vocabulary - Electrical and electronic measurements - Part 311: General terms relating to electrical measurements*

IEC 60050-351, *International electrotechnical vocabulary - Part 351: Control technology*

IEC 60068-2-1:~~1990~~, *Environmental testing - Part 2-1: Tests - Test A: Cold*

IEC 60068-2-2:~~1974~~, *Environmental testing - Part 2-2: Tests - Test B: Dry heat*

IEC 60068-2-6:~~1995~~, *Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal)*

IEC 60068-2-31:~~1969~~, *Environmental testing - Part 2-31: Tests - Test Ec: ~~Drop and topple~~ Rough handling shocks, primarily for equipment-type specimens*

~~IEC 60068-2-56:1988, Environmental testing — Part 2: Tests. Test Cb: Damp heat, steady state, primarily for equipment~~

IEC 60068-2-78, *Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state*

IEC 60381-1:~~1982~~, *Analogue signals for process control systems - Part 1: Direct current signals*

IEC 60381-2, *Analogue signals for process control systems - Part 2: Direct voltage signals*

IEC 60382:~~1991~~, *Analogue pneumatic signal for process control systems*

IEC 60529:~~1989~~, *DegreeS of protection provided by enclosures (IP Code)*

IEC 60654 (all parts), *Industrial-process measurement and control equipment - Operating conditions*

IEC 60721-3 (all parts), *Classification of environmental conditions - Part 3 Classification of groups of environmental parameters and their severities*

~~IEC 60902:1987, Industrial-process measurement and control — Terms and definitions~~

~~IEC 61000-4-3:1995, Electromagnetic compatibility (EMC) — Part 4: Testing and measurement techniques — Section 3: Radiated, radio-frequency electromagnetic field immunity test~~

~~IEC 61000-4-4:1995, Electromagnetic compatibility (EMC) — Part 4: Testing and measurement techniques — Section 4: Electrical fast transient/burst immunity test~~

~~IEC 61000-4-5:1995, Electromagnetic compatibility (EMC) — Part 4: Testing and measurement techniques — Section 5: Surge immunity test~~

~~IEC 61000-4-8:1993, Electromagnetic compatibility (EMC) — Part 4: Testing and measurement techniques — Section 8: Power frequency magnetic field immunity test~~

IEC 61010-1:~~1990~~, *Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements*

IEC 61032:~~1997~~, *Protection of persons and equipment by enclosures - Probes for verification*

~~IEC 61187:1993, Electrical and electronic measuring equipment — Documentation~~

## Bibliography

IEC 60079 (all parts), *Explosive atmospheres*

IEC 60534-1, *Industrial-process control valves - Part 1: Control valve terminology and general considerations*

IEC 60534-6-1, *Industrial-process control valves - Part 6: Mounting details for attachment of positioners to control valves - Section 1: Positioner mounting on linear actuators*

IEC 60534-6-2, *Industrial-process control valves - Part 6-2: Mounting details for attachment of positioners to control valves - Positioner mounting on rotary actuators*

IEC 60534-9, *Industrial process control valves - Part 9: Test procedure for response measurements from step inputs*

IEC 61987-24-1, *Industrial-process measurement and control - Data structures and elements in process equipment catalogues - Part 24-1: List of Properties (LOPs) of positioners and I/P converters for electronic data exchange*