

TECHNICAL SPECIFICATION

**Communication networks and systems for power utility automation -
Part 80-6: Using IEC 61850 for communication between power system
automation equipment and control or maintenance centres**

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
1.1 General.....	10
1.2 Published versions of this standard and related namespace name.....	11
1.3 Identification of the Code Components	12
1.3.1 Identification of the namespace description	12
1.3.2 Identification of the XML schema namespace	12
1.4 Code component distribution	13
2 Normative references	13
3 Terms and definitions	14
4 Abbreviated terms	15
5 Requirements	16
5.1 Communication requirements for PSAE-CC communication.....	16
5.1.1 General issues.....	16
5.1.2 Functions based on PSAE-CC communication	18
5.1.3 Message performance requirements	18
5.1.4 Introduction and use of message performance classes.....	19
5.1.5 Requirements for data and communication quality	20
5.1.6 Reliability.....	21
5.1.7 Availability	21
5.1.8 Hardware virtualization.....	21
5.1.9 Requirements concerning the communication system.....	22
5.2 Modelling requirements for PSAE-CC communication	22
6 Proxy/Gateway engineering process	23
6.1 Engineering requirements for PSAE-CC communication	23
6.2 Extension of the engineering process with SCL.....	24
6.2.1 General	24
6.2.2 Engineering workflow	24
6.2.3 Integrated engineering workflow – LANs with WAN	26
6.3 Extension of the SCL schema from IEC 61850-6	27
6.3.1 General	27
6.3.2 Modelling of redundancy	27
6.3.3 Modelling of data references between SCL files.....	33
6.3.4 Functional naming.....	34
6.4 Security aspects.....	34
7 PSAE-CC communication – Principles and models	35
7.1 Communication aspects of a Proxy/Gateway.....	35
7.1.1 Basic communication architecture	35
7.1.2 Communication architectures for direct access	36
7.1.3 Communication architectures for indirect access.....	37
7.1.4 Mapping between use cases and IEC 61850-7-2 services	40
7.2 Redundancy schemes for the PSAE-CC communication.....	44
7.2.1 General	44
7.2.2 Link states	44
7.2.3 No redundancy.....	45

7.2.4	AccessPoint redundancy	46
7.2.5	Device redundancy of frontend IEDs.....	48
7.2.6	Device redundancy of Proxy/Gateway and frontend IEDs	49
7.2.7	Multiple redundancies	50
7.2.8	Transport reliability	51
7.2.9	Link supervision	51
7.2.10	Client redundancy logic.....	52
7.2.11	Buffer Handling	52
7.2.12	Usage of buffered and unbuffered reporting	55
7.2.13	Selection guide for redundancy types	56
7.3	Functionality of a Proxy/Gateway.....	56
7.3.1	General	56
7.3.2	Indirect access.....	59
7.3.3	Indirect transparent access	59
7.3.4	Handling of communication interruptions between the Proxy/Gateway client and an IED of power utility automation system.....	60
7.4	Data Model	61
7.4.1	Abbreviated terms used in data object names	61
7.4.2	LogicalNodes_80_6 (LogicalNodes-80-6).....	62
7.4.3	Data object name semantics and enumerations	64
7.5	Proxy/Gateway data modelling aspects.....	65
7.5.1	General	65
7.5.2	Usage of Proxy and Mir in the Proxy/Gateway	66
7.5.3	Handling of Mod and Beh in the Proxy/Gateway.....	66
7.5.4	Handling of Health in the Proxy/Gateway	67
7.5.5	Handling of configuration parameters	67
7.5.6	Data modelling rules	67
7.6	Mapping of services between a Proxy/Gateway and an PUAS IED.....	89
7.6.1	General	89
7.6.2	Substitution.....	89
7.6.3	Settings	89
7.6.4	SettingGroup	89
7.6.5	Telemonitoring blocking	90
7.6.6	Telecontrol blocking	91
7.6.7	Service tracking	92
7.6.8	Control	92
7.6.9	Reporting.....	111
7.6.10	Logging	111
7.6.11	File transfer	111
7.6.12	Proxy/Gateway is transparent for FILE services	113
7.6.13	Data and communication security	113
8	SCSM aspects – MMS and ISO/IEC 8802-3.....	113
8.1	General.....	113
8.2	TCP/IP T-Profiles	114
9	SCSM aspects – Sampled values over ISO/IEC 8802-3 (IEC 61850-9-2).....	114
9.1	General.....	114
10	Conformance testing.....	115
10.1	General.....	115
10.2	Conformance test procedures	115

10.2.1	General	115
10.2.2	Test procedure requirements.....	115
10.2.3	Test structure	116
10.2.4	Test system for Proxy/Gateway devices.....	116
10.2.5	Test system for control/maintenance centre clients	117
10.2.6	Test cases to test a Proxy/Gateway device	118
10.2.7	Test cases to test a control/maintenance centre client device.....	122
Annex A (normative) Protocol Implementation Conformance Statement (PICS)		123
A.1	General.....	123
A.2	Transparent access.....	123
A.3	Redundancy support statement	124
A.4	Transformation function support statement	125
A.5	Proxy/Gateway model support statement	125
A.6	Instruction and comments on using this template	126
A.6.1	Comments	126
A.6.2	Instructions.....	126
A.6.3	Revision history	126
Annex B (informative) Extension of the ControlServiceStatusKind enumeration for multi-level control		127
Annex C (informative) PSAE-CC communication use cases		128
C.1	Overview	128
C.1.1	General	128
C.1.2	Actors.....	128
C.1.3	Use case diagram	128
C.1.4	Use cases.....	130
C.2	Telecontrol.....	131
C.2.1	General	131
C.2.2	Constraints / Assumptions / Design Considerations.....	131
C.2.3	Actors.....	131
C.2.4	Use cases diagram	131
C.2.5	Use case description.....	133
C.2.6	Sequence diagrams	133
C.3	Synchrophasors and State Estimation.....	139
C.3.1	General	139
C.3.2	Constraints / assumptions / design considerations	140
C.3.3	Actors.....	140
C.3.4	Use cases diagram	140
C.3.5	Use cases description	141
C.3.6	Sequence diagrams	141
C.4	Disturbance	142
C.4.1	General	142
C.4.2	Constraints / Assumptions / Design considerations	142
C.4.3	Actors.....	142
C.4.4	Use case diagram	142
C.4.5	Uses cases description	144
C.4.6	Sequence diagrams	144
C.5	Counting	145
C.5.1	General	145
C.5.2	Constraints / Assumptions / Design considerations	145

C.5.3	Actors	145
C.5.4	Use cases diagram	145
C.5.5	Use cases description	146
C.5.6	Sequence diagrams	146
C.6	Power quality	147
C.6.1	General	147
C.6.2	Constraints / Assumptions / Design considerations	147
C.6.3	Actors	147
C.6.4	Use cases diagram	147
C.6.5	Use cases description	148
C.6.6	Sequence diagrams	148
C.7	Asset	149
C.7.1	General	149
C.7.2	Constraints / Assumptions / Design considerations	149
C.7.3	Actors	150
C.7.4	Use cases diagram	150
C.7.5	Use cases description	150
C.7.6	Sequence diagram	150
C.8	Parameter configuration	150
C.8.1	General	150
C.8.2	Constraints / Assumptions / Design considerations	151
C.8.3	Actors	151
C.8.4	Use cases diagram	151
C.8.5	Use cases description	152
C.8.6	Sequence diagrams	152
Bibliography		153
Figure 1	Connectivity and communication paths of power system automation equipment	11
Figure 2	Levels and logical interfaces in power utility automation systems.....	17
Figure 3	Definition of transfer time t	19
Figure 4	Scope of separated engineering workflow	24
Figure 5	Engineering workflow	26
Figure 6	Scope of integrated workflow	27
Figure 7	Communication concept	35
Figure 8	PSAE-CC communication with direct access	37
Figure 9	Basic configuration for indirect access	39
Figure 10	Configuration without redundancy	46
Figure 11	AccessPoint redundancy.....	47
Figure 12	Device redundancy of frontend IEDs	48
Figure 13	Device redundancy of Proxy/Gateway and frontend IEDs.....	49
Figure 14	Multiple redundancies.....	50
Figure 15	Usage of buffers and duplicate filter.....	54
Figure 16	Usage of the DOs Proxy and Mir in the Proxy Gateway context	58
Figure 17	Comparison of indirect, indirect transparent and direct access.....	59
Figure 18	Class diagram LogicalNodes-80-6::LogicalNodes-80-6	62
Figure 19	Class diagram LNGroupL-80-6::LNGroupL-80-6	62

Figure 20 – Class diagram DOEnums-80-6::DOEnums-80-6	65
Figure 21 – Product related naming Proxy/Gateway	69
Figure 22 – Function related naming Proxy/Gateway	71
Figure 23 – Modelling a Proxy/Gateway IED – Preserving the logical devices	73
Figure 24 – Modelling a Proxy/Gateway IED – Renaming of logical devices	74
Figure 25 – Modelling a Proxy/Gateway IED – Rearranging logical nodes	76
Figure 26 – Modelling a Proxy/Gateway IED – Merging of logical nodes	78
Figure 27 – Modelling a Proxy/Gateway IED – Splitting of logical nodes	80
Figure 28 – Modelling a Proxy/Gateway IED – Transform to semantically defined LN	82
Figure 29 – Modelling a Proxy/Gateway IED – Convert semantically defined LNs	84
Figure 30 – Modelling a Proxy/Gateway IED - Create an array subset	86
Figure 31 – Principle of the Proxy/Gateway control model	92
Figure 32 – State machine of direct control with normal security	98
Figure 33 – Direct control with normal security – positive case	99
Figure 34 – Direct control with normal security – negative case	100
Figure 35 – State machine of SBO control with normal security	101
Figure 36 – SBO control with normal security – positive case	102
Figure 37 – SBO control with normal security – negative case	103
Figure 38 – State machine of direct control with enhanced security	104
Figure 39 – Direct control with enhanced security – positive case	105
Figure 40 – Direct control with enhanced security – negative case	106
Figure 41 – State machine of SBO control with enhanced security	107
Figure 42 – SBO control with enhanced security – positive case	108
Figure 43 – SBO control with enhanced security – negative case	110
Figure 44 – Overview of functionality and services	113
Figure 45 – Routable sampled values – Overview of used services	114
Figure 46 – Test system architecture to test a Proxy/Gateway device	117
Figure 47 – Test system architecture to test a redundant control/maintenance centre client device	118
Figure C.1 – Use case diagram for PSAE to control centre communication	129
Figure C.2 – Telecontrol use case diagram	132
Figure C.3 – Principle of data forwarding, depending on the operation mode	139
Figure C.4 – State estimation using synchrophasors	140
Figure C.5 – Disturbance use cases diagram	143
Figure C.6 – Counting use cases diagram	146
Figure C.7 – Power quality use cases diagram	148
Figure C.8 – Core electric utility processes involving asset management	149
Figure C.9 – Asset supervision use case diagram	150
Figure C.10 – Parameter configuration use cases diagram	151
Table 1 – Tracking information of IEC 61850-80-6:2022A namespace building-up	8
Table 2 – Reference between published versions of the standard and related namespace names	11
Table 3 – Attributes of IEC 61850-80-6:2022A namespace	12

Table 4 – Attributes of the IEC TS 61850-80-6 XML namespace	12
Table 5 – Typical Transfer time requirements for control and monitoring data.....	20
Table 6 – Attributes of the eIEC61850-80-6:RedundancyModes element	28
Table 7 – Attributes of the eIEC61850-80-6:LinkModes element.....	29
Table 8 – Elements of the eIEC61850-80-6:ClientRedundancyServices element.....	30
Table 9 – Attributes of the eIEC61850-80-6:RedundantServerTo element	31
Table 10 – Attributes of the eIEC61850-80-6:RedundantClientTo element.....	32
Table 11 – Values of the eIEC61850-80-6:tLinkModeEnum	33
Table 12 – Attributes of the eIEC61850-80-6:ProxyOf element.....	34
Table 13 – Mapping use cases to IEC 61850-7-2 services	41
Table 14 – Link states of an association	44
Table 15 – Usage of buffered / unbuffered reporting for the redundancy type	55
Table 16 – Requirements versus redundancy type	56
Table 17 – Data objects of LTPA.....	63
Table 18 – Name and description of data objects defined in classes of LogicalNodes- 80-6 package.....	64
Table 19 – Generic behaviour and negative responses	93
Table 20 – Mapping of Comtrade folder names in the Proxy/Gateway	112
Table 21 – Data model mapping positive test cases.....	118
Table 22 – Server positive test cases	119
Table 23 – Substitution positive test cases	119
Table 24 – Setting group control positive test cases	120
Table 25 – Setting group control negative test cases	120
Table 26 – Control positive test cases	120
Table 27 – File transfer positive test cases.....	121
Table 28 – Telemonitoring blocking positive test cases	121
Table 29 – Telecontrol blocking positive test cases.....	121
Table 30 – Redundancy positive test cases	122
Table 31 – Telemonitoring blocking positive test cases	122
Table 32 – Redundancy positive test cases	122
Table A.1 – Transparent access conformance statement	123
Table A.2 – Redundancy mechanism support statement	124
Table A.3 – Proxy/Gateway transformation function support statement.....	125
Table A.4 – Proxy/Gateway model support statement	125
Table B.1 – Literals of ControlServiceStatusKind extension	127
Table C.1 – Constraints for acquisition of status	134
Table C.2 – Constraints for acquisition of alarms	135
Table C.3 – Constraints for remote control	135
Table C.4 – Forwarding of information depending on the operation mode	138

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**Communication networks and systems for power utility automation -
Part 80-6: Using IEC 61850 for communication between power system
automation equipment and control or maintenance centres**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 61850-80-6 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
57/2922/DTS	57/2962/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

This IEC publication includes Code Components i.e. components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS> or otherwise is clearly labelled in this standard as a Code Component.

The purchase of this IEC publication carries a copyright license for the purchaser to sell software containing Code Components from this standard to end users either directly or via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

Table 1 shows all tracking information of IEC 61850-80-6:2022A namespace building-up:

Table 1 – Tracking information of IEC 61850-80-6:2022A namespace building-up

Attribute	Content
Namespace IEC specific information	
Version of the UML model used for generating the document (informative)	WG10build25
Date of the UML model used for generating the document (informative)	2026-07-28
Autogeneration software name and version(informative)	j61850DocBuilder 02.06beta based on jCleanCim beta9.4 (derived from jCleanCim 02-02)

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

Following the publication of IEC 61850, substations using IEC 61850 technologies have been implemented. The concepts of IEC 61850 are also used in applications outside of the substation such as distributed energy resources, hydro power plants and wind power plants. Therefore, IEC 61850 forms the foundation for a globally standardized utility communication network. In the context of this technical specification IEDs in substations or those used in other, above-mentioned applications, will be referred to as 'power system automation equipment' (PSAE). The term 'power utility automation systems' is used for substation automation and other automation systems in the power utility domain.

IEC 62357-1 describes the reference architecture for power systems management and associated information exchange. The communication between power system automation equipment and a control centre relate to the information exchange between the station and operation zone in the SGAM model. Beneath other classic telecontrol protocols IEC 62357-1 proposes the use of IEC 61850 for this purpose.

IEC 61850 was initially prepared for information exchange between the devices of a substation automation system. The concepts are now also used in other power system application domains.

The object models and configuration language introduced by IEC 61850 provide new possibilities for the management of the automation system. A direct and seamless access from the control and maintenance centres to the IEDs of the power utility automation system allows efficient data management of the overall control system.

This technical specification provides a comprehensive overview of the matters that need to be considered to use IEC 61850 for information exchange between power system automation equipment and control or maintenance systems.

A similar report discussing the use of IEC 61850 for communication between substations has been issued as IEC TR 61850-90-1. This document was developed as a TS version of IEC TR 61850-90-2.

Currently, power system automation equipment configuration information is available in the SCL. Control centre configuration information is available in the CIM model. The models have been harmonized, so that an automatic transfer of the information from one model to the other is possible. New work will describe how that configuration information can be transferred between CIM and SCL. However, this document does not address the overall topic of CIM/IEC 61850 harmonisation. That is addressed separately in IEC TR 62361-102.

1 Scope

1.1 General

This part of IEC 61850, which is a technical specification, provides a comprehensive overview of the various aspects that need to be considered while using IEC 61850 for information exchange between power system automation equipment and control or maintenance centres or other system level applications. This document:

- defines use cases and communication requirements that require an information exchange between power system automation equipment and control or maintenance centres;
- describes the usage of the configuration language of IEC 61850-6;
- gives guidelines for the selection of communication services and architectures compatible with IEC 61850;
- describes the engineering workflow;
- introduces the use of a Proxy/Gateway concept;
- describes the links regarding the Specific Communication Service Mapping (SCSM);
- defines the abstract conformance test cases that build the basis for the conformance test procedures elaborated by the UCAIug Testing Sub Committee.

This document does not define constraints or limitations for specific device implementations. There is no specific clause for cyber security, which is tackled when it is necessary. The model for IEC TS 61850-80-6 provides security functions based upon the security threats and security functions found in IEC TS 62351-1 and IEC TS 62351-2. This document touches on several security aspects with the following basic assumptions:

- Information authentication and integrity (e.g., the ability to provide tamper detection) is needed.
- In case of operational issues, encryption (to achieve confidentiality) is optional. This typically applies for GOOSE and SV messages in the power utility automation system LAN.

End-to-end information authentication and integrity methods, regardless of information hierarchies, need to be provided. The typical method to provide this security function is through some type of information/message authentication code. IEC 62351-4 and IEC 62351-9 describe how authentication and integrity is achieved for IEC 61850-8-1. IEC 62351-4 provides means to ensure end-to-end data integrity through Proxy/Gateways.

Beneath information authentication and integrity, information availability is an important aspect for telecontrol. This document provides redundancy architectures to enhance the availability of information in control and maintenance centres.

The scheme shown in Figure 1 gives an overview of the connectivity and the communication paths. It indicates the principle to access directly or indirectly – via the Proxy/Gateway – to an IED. An application of security controls for power system automation equipment to control centre communication can be found in IEC 62351-10:2012, 6.4.3. Thus, the power system automation equipment is considered to be inside a perimeter of cyber security. The access is totally checked by network security access points (this document does not describe such a network security access point). The boundary of the electronic security perimeter is defined by the point, where the communication line leaves the perimeter of the power utility automation system over public ground. There can be more than one network security access point, where separation of applications (e.g., control centre and maintenance centre) is required. When more than one client needs access to the same network security access point information level access control, e.g. according to IEC TS 62351-8, can be added. IEC TS 62351-8 can also be used in other cases, where different access rights are required.



Most applications for which this document is applicable will use the services of MMS (ISO 9506) mapped to ISO/IEC 8802-3 frame formats, as described in IEC 61850-8-1.

1.2 Published versions of this standard and related namespace name

Table 2 – Reference between published versions of the standard and related namespace names

1.3 Identification of the Code Components

1.3.1 Identification of the namespace description

The namespace associated with this document is an NSD (Namespace Definition) file as defined in IEC 61850-7-7.

NOTE The NSD files are distributed as a Full (complete machine-readable file) Code Component and as a Light (reduced machine-readable content version) Code Component.

Table 3 shows all attributes of the IEC 61850-80-6:2022A namespace.

Table 3 – Attributes of IEC 61850-80-6:2022A namespace

Attribute	Content
Namespace nameplate	
Namespace Identifier	IEC 61850-80-6
Version	2022
Revision	A
Release	3
Full Namespace Name	IEC 61850-80-6:2022A
Full Code Component Name	IEC TS 61850-80-6.NSD.2022A3.Full
Light Code Component Name	IEC TS 61850-80-6.NSD.2022A3.Light
Namespace Type	domain
Namespace dependencies	
includes	IEC 61850-7-4:version :2007 revision :B

1.3.2 Identification of the XML schema namespace

The second namespace associated with this document is an XML schema (XSD) for an extension to the System Configuration Language (SCL) as defined in IEC 61850-6. The parameters which identify the namespace are provided in Table 4.

Table 4 – Attributes of the IEC TS 61850-80-6 XML namespace

Attribute	Content
Namespace nameplate	
Namespace Identifier (xmlns)	http://www.iec.ch/61850/2022/SCL/80-6
Version	2022
Revision	A
Release	2
XSD version header attribute	2022A2
Recommended reference name	eIEC 61850-80-6
Code Component Name	IEC 61850-80-6.SCL.2022A2.Full
Namespace dependencies	
includes	http://www.iec.ch/61850/2003/SCL version :2007 revision :C release :5

1.4 Code component distribution

Each Code Component is a ZIP package containing the electronic representation of the Code Component itself, with a file describing the content of the package (IECManifest.xml).

The life cycle of a Code Component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, Version (corresponding to an edition) and Revision (corresponding to an amendment). A third publication stage (Release) allows publication of Code Component in case of urgent fixes of InterOp Tissues, thus without need to publish an amendment.

Consequently, new release(s) of the Code Component might be released, which supersede(s) the previous release, and will be distributed through the IEC TC57 web site at: <http://www.iec.ch/tc57/supportdocuments>.

The latest version/release of a Code Component will be found by selecting the file for the Code Component with the highest value for VersionStateInfo, e.g. {VersionStateInfo}.Full.zip.

For conformance testing, implementations should always use the latest downloadable Code Components, as the Code Components might be subject to updates. See technical corrigenda and XSD history files.

When the Code Components associated with this document have a full version and a light version, the light version is freely accessible.

When the Code Components associated with this document have a full version only, the full version is freely accessible.

The freely accessible Code Components are available on the IEC website for download at: <http://www.iec.ch/tc57/supportdocuments>, but the usage remains under the licensing conditions.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-6:2009, *Communication networks and systems for power utility automation - Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-1:2011, *Communication networks and systems for power utility automation - Part 7-1: Basic communication structure - Principles and models*

IEC 61850-7-2:2010, *Communication networks and systems for power utility automation - Part 7-2: Basic information and communication structure - Abstract communication service interface (ACSI)*

IEC 61850-7-4:2010, *Communication networks and systems for power utility automation - Part 7-4: Basic communication structure - Compatible logical node classes and data object classes*

IEC 61850-8-1:2011, *Communication networks and systems for power utility automation - Part 8-1: Specific communication service mapping (SCSM) - Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

IEC 61850-9-2, *Communication networks and systems for power utility automation - Part 9-2: Specific communication service mapping (SCSM) - Sampled values over ISO/IEC 8802-3*

IEC 61850-10:2012, *Communication networks and systems for power utility automation - Part 10: Conformance testing*

IEC TR 61850-90-12:2020, *Communication networks and systems for power utility automation - Part 90-12: Wide area network engineering guidelines*

Bibliography

- IEC 60870-4, *Telecontrol equipment and systems - Part 4: Performance requirements*
- IEC 60870-5-101, *Telecontrol equipment and systems - Part 5-101: Transmission protocols - Companion standard for basic telecontrol tasks*
- IEC 60870-5-103, *Telecontrol equipment and systems - Part 5-103: Transmission protocols - Companion standard for the informative interface of protection equipment*
- IEC 60870-5-104, *Telecontrol equipment and systems - Part 5-104: Transmission protocols - Network access for IEC 60870-5-101 using standard transport profiles*
- IEC 61158-6, *Industrial communication networks - Fieldbus specifications*
- IEC TS 61850-2, *Communication networks and systems for power utility automation - Part 2: Glossary*
- IEC 61850-4, *Communication networks and systems for power utility automation - Part 4: System and project management*
- IEC 61850-5:2013, *Communication networks and systems for power utility automation - Part 5: Communication requirements for functions and device models*
- IEC 61850-7-3, *Communication networks and systems for power utility automation - Part 7-3: Basic communication structure – Common data classes*
- IEC TS 61850-7-7, *Communication networks and systems for power utility automation - Part 7-7: Machine-processable format of IEC 61850-related data models for tools*
- IEC TR 61850-7-500, *Communication networks and systems for power utility automation - Part 7-500: Basic information and communication structure - Use of logical nodes for modelling application functions and related concepts and guidelines for substations*
- IEC TR 61850-90-3, *Communication networks and systems for power utility automation - Part 90-3: Using IEC 61850 for condition monitoring diagnosis and analysis*
- IEC TR 61850-90-5, *Communication networks and systems for power utility automation - Part 90-5: Use of IEC 61850 to transmit synchrophasor information according to IEEE C37.118*
- IEC TR 61850-90-10, *Communication networks and systems for power utility automation - Part 90-10: Models for scheduling*
- IEC TR 61850-90-11, *Communication networks and systems for power utility automation - Part 90-11: Methodologies for modelling of logics for IEC 61850 based applications*
- IEC TR 61850-90-16, *Communication networks and systems for power utility automation - Part 90-16: Requirements of system management for Smart Energy Automation*
- IEC TR 61850-90-17, *Communication networks and systems for power utility automation - Part 90-17: Using IEC 61850 to transmit power quality data*
- IEC TR 61850-90-20, *Communication networks and systems for power utility automation - Part 90-20: Guideline to redundancy systems*
- IEC 62056-6, *Electricity metering data exchange - The DLMS/COSEM suite*

IEC TS 62351-1, *Power systems management and associated information exchange - Data and communications security - Part 1: Communication network and system security - Introduction to security issues*

IEC TS 62351-2, *Power systems management and associated information exchange - Data and communications security - Part 2: Glossary of terms*

IEC 62351-4, *Power systems management and associated information exchange - Data and communications security - Part 4: Profiles Including MMS and derivatives*

IEC 62351-6, *Power systems management and associated information exchange - Data and communications security - Part 6: Security for IEC 61850*

IEC 62351-8, *Power systems management and associated information exchange - Data and communications security - Part 8: Role-based access control for power system management*

IEC 62351-9, *Power systems management and associated information exchange - Data and communications security - Part 9: Cyber security key management for power system equipment*

IEC TR 62351-10, *Power systems management and associated information exchange - Data and communications security - Part 10: Security architecture guidelines*

IEC 62351-11, *Power systems management and associated information exchange - Data and communications security - Part 11: Security for XML documents*

IEC TR 62357-1, *Power systems management and associated information exchange - Part 1: Reference architecture*

IEC TS 62361-102, *Power systems management and associated information exchange - Interoperability in the long term - Part 102: CIM - IEC 61850 harmonization*

IEC 62682, *Management of alarm systems for the process industries*

IEC 81346-1, *Industrial systems, installations and equipment and industrial products - Structuring principles and reference designations - Part 1: Basic rules*

IEC 81346-2, *Industrial systems, installations and equipment and industrial products - Structuring principles and reference designations - Part 2: Classification of objects and codes for classes*

IEEE C37.118.1, *IEEE Standard for Synchrophasor Measurements for Power Systems*

IEEE C37.118.2, *IEEE Standard for Synchrophasor Data Transfer for Power Systems*

IEEE 1815-2012, *IEEE Standard for Electric Power Systems Communications-Distributed Network Protocol (DNP3)*

ISO 9506-1:2003, *Industrial automation systems - Manufacturing Message Specification - Part 1: Service definition*

ISO 9506-2:2003, *Industrial automation systems - Manufacturing Message Specification - Part 2: Protocol specification*

RFC 1122:1989, *Requirements for Internet Hosts - Communication Layers*