

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Low-voltage surge protective devices –
Part 11: Surge protective devices connected to AC low-voltage power systems –
Requirements and test methods**

**Parafoudres basse tension –
Partie 11: Parafoudres connectés aux réseaux basse tension en courant
alternatif – Exigences et méthodes d'essai**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions and abbreviated terms	9
3.1 Terms and definitions.....	9
4 Classification.....	9
4.13 End-of-life mode of the SPDA	9
4.100 Power system	9
4.100.1 AC between 47 Hz and 63 Hz	9
4.100.2 AC other than the range of 47 Hz to 63 Hz.....	9
5 Void.....	9
6 Marking and other product information.....	9
6.2 List of items	9
6.2.100 Markings which are required on the body, or permanently attached to the body, of the SPD	10
6.2.101 Information to be provided by the manufacturer	10
6.2.102 Information which shall be provided by the manufacturer for type testing, as applicable	10
7 Service conditions	10
7.100 Frequency.....	10
8 Requirements	10
8.3 Electrical requirements	10
8.3.9 Behaviour under temporary overvoltages.....	11
8.5 Environmental and material requirements	11
8.5.5 Ageing behaviour under damp heat	11
8.6.100 Portable SPDs defined as pluggable equipment type A	11
9 Tests	11
9.1 Type testing procedures.....	11
9.1.1 General	11
9.3 Electrical tests	16
9.3.3 Protective conductor current I_{PE}	16
9.3.5 Operating duty test	16
9.3.6 Safety performance of overstressed SPDs.....	16
9.3.9 Behaviour under temporary overvoltages (TOVs).....	20
9.5 Environmental and material tests	24
9.5.5 Life test under damp heat	24
Annex AA (normative) Application of annexes from IEC 61643-01	25
Annex BB (normative) Test voltages for SPDs – U_{test}	26
Annex CC (normative) TOV Ratings.....	32
CC.1 Overview	32
CC.2 TOV ratings based on IEC 60364-4-44:2024, Clause 442	32
CC.3 Other TOV ratings for specific distribution systems or countries.....	33
CC.3.1 General	33
CC.3.2 North American systems	33

CC.3.3 Japanese systems	34
Annex DD (normative) Reduced test procedures	35
Annex EE (normative) Portable SPDs defined as pluggable equipment type A	37
EE.1 General	37
EE.2 Additional requirements	37
EE.3 Modified test requirements	38
EE.3.1 Test at low short-circuit current	38
EE.3.2 Dedicated overstress test	38
EE.3.3 Behaviour under temporary overvoltages (TOVs)	38
Bibliography	40
Figure 100 – Test circuit for the dedicated overstress test	19
Figure 101 – Timing diagram for the dedicated overstress test	19
Figure 102 – Example of a test circuit to perform the test under TOVs caused by faults in the low voltage system	21
Figure 103 – Timing diagram for the test under TOVs caused by faults in the low voltage system	22
Figure 104 – Example of a test setup for testing SPDs for use in TT systems under TOVs caused by faults in high (medium) voltage systems	23
Figure 105 – Timing diagram for use in testing SPDs under TOVs caused by faults in the high (medium) voltage system using the circuit of Figure 104	24
Table 100 – Type test requirements for SPDs	13
Table 101 – Prospective short-circuit current and power factor	17
Table AA.1 – Application of annexes from IEC 61643-01	25
Table BB.1 – Test voltage values	27
Table BB.2 – Test voltage values for Japanese systems	31
Table CC.1 – TOV test values for systems complying with IEC 60364 series	33
Table CC.2 – TOV test parameters for North American systems	34
Table CC.3 – TOV test parameters for Japanese systems	34
Table DD.1 – Reduced test procedure for SPDs complying with IEC 61643-11:2011	35
Table EE.1 – TOV test values for systems complying with IEC 60364 series for portable SPDs	39
Table EE.2 – TOV test parameters for Japanese systems	39

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SURGE PROTECTIVE DEVICES –**Part 11: Surge protective devices connected to AC low-voltage power systems – Requirements and test methods****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61643-11 has been prepared by subcommittee 37A: Low-voltage surge protective devices, of IEC technical committee 37: Surge arresters. It is an International Standard.

This second edition cancels and replaces the first edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Specific requirements for SPDs for AC applications are now contained in this document, whereas the common requirements for all SPDs are now contained in IEC 61643-01;
- b) Clarification on test application either to a complete SPD, to a "mode of protection", or to a complete "SPD assembly";

- c) Additional measurement of voltage protection level on "combined modes of protection" between live conductors and PE;
- d) Additional duty test for T1 and T2 SPDs with follow current to check variation of the follow current value at lower impulse currents;
- e) Modified and amended short circuit current test requirements to better cover up to date internal SPD disconnecter technologies;
- f) Improved dielectric test requirements for the SPD's main circuits and added dielectric test requirements for "electrically separated circuits";
- g) Additional clearance requirements for "electrically separated circuits".

The requirements of this document supplement, modify or replace certain of the general requirements contained in IEC 61643-01 and shall be read and applied together with the latest edition of IEC 61643-01, as indicated by the undated normative reference in Clause 2 of this document.

Numbering of clauses follows the numbering of IEC 61643-01, but, dependent on the application of clauses from IEC 61643-01, does not necessarily follow sequentially.

If a clause in IEC 61643-01 is not explicitly called up or referred to in this document, then this clause does not apply to SPDs covered by this document. Any instructions in this document calling up clauses from IEC 61643-01 are written in *Italic type*.

NOTE In other words, if e.g. Clause 4 is called up in this document all subclauses of Clause 4 of IEC 61643-01 are applied without modification. But, if e.g. some modifications are required on subclauses of Clause 9 of IEC 61643-01, then the relevant second level subclauses of IEC 61643-01 (e.g. 9.3, 9.5 etc.) are called up separately and it is indicated how they are applied.

The numbering of additional subclauses to IEC 61643-01 in this document starts with the number 100 in the last section of the subclause added (see e.g. 4.100). The numbering of additional tables and figures to IEC 61643-01 in this document starts with the number 100.

The text of this International Standard is based on the following documents:

Draft	Report on voting
37A/427/FDIS	37A/431/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61643 series, published under the general title *Low-voltage surge protective devices*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

The content of the corrigendum 1 (2026-10) has been included in this copy.

INTRODUCTION

It has been assumed in the drafting of this International Standard that the execution of its provisions is entrusted to appropriately qualified and experienced persons.

This document recognizes the internationally accepted level of protection against hazards such as electrical, mechanical, thermal, fire and radiation of SPDs when operated as in normal use taking into account the manufacturer's instructions. It also covers abnormal situations that can be expected in practice.

This document takes into account the requirements of IEC 60364 as far as possible so that there is compatibility with the wiring rules when the SPD is connected to the supply mains. However, national wiring rules might differ.

If the intended applications of an SPD are covered by different parts of the IEC 61643-X1 series, all relevant parts are applied, as far as is reasonable.

This document addresses safety and performance tests for surge protective devices (SPDs) for AC applications in conjunction with IEC 61643-01.

This document addresses T1 SPD, T2 SPD and T3 SPD according to IEC 61643-01.

IEC 61643-12 addresses the selection and application principles of SPDs.

LOW-VOLTAGE SURGE PROTECTIVE DEVICES –

Part 11: Surge protective devices connected to AC low-voltage power systems – Requirements and test methods

1 Scope

This document, together with IEC 61643-01, is applicable to devices for surge protection against indirect and direct effects of lightning or other transient overvoltages.

These devices are intended to be connected to AC power circuits and equipment rated up to 1 000 V RMS, the preferred frequencies taken into account in this document are 50/60 Hz. Other frequencies are not excluded. Performance and safety requirements, tests and ratings are specified in this document. These devices contain at least one nonlinear component and are intended to limit surge voltages and divert surge currents.

The test requirements provided by this document are based on the assumption that the SPD is connected to an AC power circuit fed by a power source providing a linear voltage-current characteristic. When the SPD is to be connected to a different kind of source or to a different frequency, careful consideration is required. This mainly applies with regard to system and fault conditions to be expected in such a system (e.g. expected short circuit current, TOV-stresses).

This document can apply for railway applications, when related product standards do not exist for that area or for certain applications.

Based on a risk assessment it might not be necessary to apply all requirements of this document to SPDs designed for specific power applications only, e.g. circuits with a low power capability, circuits supplied by nonlinear sources, circuits with protective separation from the utility supply.

NOTE 1 More information on risk assessment is provided in IEC Guide 116.

NOTE 2 Other exclusions based on national regulations are possible.

2 Normative references

For the purposes of this document the normative references given in IEC 61643-01 with the following additions apply.

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-44:2024, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 61643-01, *Low-voltage surge protective devices – Part 01: General requirements and test methods*

Bibliography

IEC 60038:2009, *IEC standard voltages*
IEC 60038:2009/AMD1:2021
