



IEC TR 61000-4-40

Edition 1.0 2020-03

TECHNICAL REPORT



**Electromagnetic compatibility (EMC) –
Part 4-40: Testing and measurement techniques – Digital methods for the
measurement of power quantities of modulated or distorted signals**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.100.01

ISBN 978-2-8322-7907-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 General	7
5 Modulated sine waveforms used in this document to compare measurement algorithms	9
5.1 General	9
5.2 Half-wave rectification	10
5.3 Full-wave rectification	10
5.4 Multi-cycle symmetrical control	11
5.5 Random on-off control	12
6 Measurement algorithms	12
6.1 General	12
6.2 Averaging algorithms	12
6.2.1 General	12
6.2.2 Performance of the averaging algorithm	13
6.2.3 Instrumental errors of the averaging algorithm	18
6.3 Smoothing filter algorithm	19
6.3.1 Frequency and step response	19
6.3.2 Verification of the smoothing filter algorithm	21
6.3.3 Instrumental errors of the filtering algorithm	25
7 Conclusions	25
Annex A (informative) Smoothing filter studied in this document	27
A.1 Algorithm	27
A.2 General C++ class program code	31
Bibliography	34
 Figure 1 – Typical resistive load current and supply voltage waveform of half-wave rectification	10
Figure 2 – Typical full-bridge rectifier current and supply voltage waveforms	11
Figure 3 – Current and voltage patterns in an MCSC circuit, (left) 1/3 MCSC and (right) 2/3 MCSC	11
Figure 4 – Amplitude of 50 Hz current with on and off periods varying within a 1 min to 2 min range	12
Figure 5 – Step response of an algorithm in Formula (6) with a half-cycle, 1-cycle and 10-cycle measurement interval	14
Figure 6 – RMS current and active power for half-wave rectification	15
Figure 7 – Sliding average RMS current and active power of a device controlled with a 1/3 MCSC circuit	15
Figure 8 – Worst case 1/3 MCSC circuit active power calculation variation	16
Figure 9 – Example of a 10 min sliding average power calculation for a load having a 92 s period	17
Figure 10 – Active power of randomly fluctuating load averaged over a sliding 10 min interval	18

Figure 11 – Sensitivity of the full-bridge rectifier RMS current and active power measurement to time interval error of single-cycle sliding average calculation	19
Figure 12 – Comparison of the first and the 10 th order filters used to estimate RMS current of a step signal	20
Figure 13 – Filter frequency responses	20
Figure 14 – Filter step responses	20
Figure 15 – Output of the 10 th order smoothing filter used to calculate the active power of a signal with a step change	21
Figure 16 – Delay and response time of a 10 th order filter used to assess the sinusoidal current of a sinusoidal waveform	22
Figure 17 – Measurement of the current and power of a half-wave rectified signal using a smoothing filter with a 10 Hz cut-off frequency	22
Figure 18 – Power quantities in full wave rectification assessed using a smoothing filter with 16,667 Hz cut-off frequency	23
Figure 19 – MCSC 1/3 pattern power quantities filtered with approximately 5,556 Hz cut-off frequency	23
Figure 20 – Active power of a load having a 92 s period measured with different algorithms	24
Figure 21 – Active power of randomly fluctuating load measured using different algorithms	25
Table 1 – Calculated power of 2/3 MCSC for different measurement windows	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –**Part 4-40: Testing and measurement techniques –
Digital methods for the measurement of power quantities
of modulated or distorted signals****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61000-4-40, which is a Technical Report, has been prepared by subcommittee SC77A: EMC – Low frequency phenomena, of IEC technical committee TC 77: Electromagnetic compatibility.

The text of this Technical Report is based on the following documents:

Enquiry draft	Report on voting
77A/1055/DTR	77A/1065/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility (EMC)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61000 is published in separate parts, according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description levels

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as International Standards, Technical Specifications or Technical Reports, some of which have already been published as sections. Others are and will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-6-1).

This document gives the rationale for the assessment of electrical power quantities (RMS voltage, RMS current and active power) under non-stationary conditions. It explains and compares two digital methods that can be used in digital measurement instrumentation to either average or filter the signals when measuring fluctuating loads, and algorithms for the realization of both methods. The examples relate to 50 Hz or 60 Hz power systems because power quantity assessments are predominantly required for these systems.

The digital averaging or integration algorithm is evaluated for fluctuating, or non-stationary, conditions, as is a digital filtering algorithm that emulates the traditional analogue power meter.

This document aims to illustrate the application of the two measurement algorithms given above to characterize existing, and commonly found, non-stationary loads, which have been selected to help interpret the measurement results obtained using both algorithms.

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-40: Testing and measurement techniques – Digital methods for the measurement of power quantities of modulated or distorted signals

1 Scope

This part of IEC 61000, which is a Technical Report, deals with the assessment of electrical power quantities (RMS voltage, RMS current and active power). It explains and compares two digital algorithms suitable for power quantity measurements in fluctuating or non-periodic loads. The examples are from 50 Hz or 60 Hz power systems.

This document does not attempt to cover all possible digital implementations of the algorithms used for power quantity assessment in fluctuating loads, for example in the context of the EMC assessment described in several IEC documents. Rather, it compares averaging with one of the filtering algorithms. This document aims to highlight some examples of applications that illustrate how the presented algorithms work. Further, guidance is given for quantifying the accuracy of each approach.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the cited edition applies. For undated references, the latest edition of the referenced document applies, including any amendments.

IEC TR 61000-1-7:2016, *Electromagnetic compatibility (EMC) – Part 1-7: General – Power factor in single phase systems under non-sinusoidal conditions*